

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-01A North Dining Room Drinking Fountain	7/30/16 12:31 PM	8/5/2016	1608182-01A	COPPER	0.5 PPM	1.3 PPM
50-02A North Dining Snack Shack Sink Faucet	7/30/16 12:32 PM	8/6/2016	1608182-02A	COPPER	0.4 PPM	1.3 PPM
50-03A Kitchen Side Wall Sink Faucet	7/30/16 12:30 PM	8/5/2016	1608182-03A	COPPER	0.3 PPM	1.3 PPM
50-04A Kitchen Center Sink Faucet	7/30/16 12:34 PM	8/6/2016	1608182-04A	COPPER	0.4 PPM	1.3 PPM
50-05A Kitchen Back Wall Sink Faucet	7/30/16 1:10 PM	8/5/2016	1608182-05A	COPPER	0.4 PPM	1.3 PPM
50-06A Cafeteria Drinking Fountain (Left)	7/30/16 12:37 PM	8/5/2016	1608182-06A	COPPER	0.4 PPM	1.3 PPM
50-07A Cafeteria Drinking Fountain (Right)	7/30/16 12:37 PM	8/5/2016	1608182-07A	COPPER	0.3 PPM	1.3 PPM
50-08A Room 18 Drinking Fountain	7/30/16 4:33 PM	8/5/2016	1608182-08A	COPPER	0.8 PPM	1.3 PPM
50-09A Room 10 Sink Faucet (Left)	7/30/16 12:44 PM	8/5/2016	1608182-09A	COPPER	0.2 PPM	1.3 PPM
50-10A Room 10 Sink Faucet (Right)	7/30/16 12:44 PM	8/5/2016	1608182-10A	COPPER	0.6 PPM	1.3 PPM
50-11A Room B-3 Sink Faucet (Left)	7/30/16 1:01 PM	8/5/2016	1608182-11A	COPPER	0.2 PPM	1.3 PPM
50-12A Room B-3 Sink Faucet (Right)	7/30/16 1:01 PM	8/5/2016	1608182-12A	COPPER	0.2 PPM	1.3 PPM
50-13A Auxillary Gymnasium Drinking Fountain	7/30/16 1:44 PM	8/7/2016	1608182-13A	COPPER	0.9 PPM	1.3 PPM
50-14A Room 100 Sink Faucet	7/30/16 1:46 PM	8/5/2016	1608182-14A	COPPER	0.4 PPM	1.3 PPM
50-15A Room 185 Sink Faucet	7/30/16 1:53 PM	8/5/2016	1608182-15A	COPPER	0.2 PPM	1.3 PPM
50-16A Hall Drinking Fountain 1	7/30/16 1:52 PM	8/6/2016	1608182-16A	COPPER	0.5 PPM	1.3 PPM
50-17A Room 182 Sink Faucet	7/30/16 1:48 PM	8/6/2016	1608182-17A	COPPER	0.2 PPM	1.3 PPM
50-18A Hall Drinking Fountain 2	7/30/16 1:50 PM	8/6/2016	1608182-18A	COPPER	0.2 PPM	1.3 PPM
50-19A Staff Room Sink Faucet (Left)	7/30/16 1:55 PM	8/6/2016	1608182-19A	COPPER	0.4 PPM	1.3 PPM
50-20A Staff Room Sink Faucet (Right)	7/30/16 1:55 PM	8/6/2016	1608182-20A	COPPER	0.4 PPM	1.3 PPM
50-22A Auditorium Hall W Drinking Fountain	7/30/16 1:57 PM	8/6/2016	1608182-21A	COPPER	0.3 PPM	1.3 PPM
50-23A Hall Outside Theater Sink Faucet	7/30/16 1:59 PM	8/6/2016	1608182-22A	COPPER	0.5 PPM	1.3 PPM
50-24A Room 151 Sink Faucet (Left)	7/30/16 2:02 PM	8/6/2016	1608182-23A	COPPER	0.5 PPM	1.3 PPM
50-25A Room 151 Sink Faucet (Right)	7/30/16 2:02 PM	8/6/2016	1608182-24A	COPPER	0.5 PPM	1.3 PPM
50-26A Auditorium Hall South Drinking Fountain 3	7/30/16 2:02 PM	8/6/2016	1608182-25A	COPPER	0.6 PPM	1.3 PPM
50-27A Room 146 Sink Faucet	7/30/16 2:10 PM	8/6/2016	1608182-26A	COPPER	0.4 PPM	1.3 PPM
50-28A Hall Drinking Fountain Near Custodial Office 4	7/30/16 2:10 PM	8/6/2016	1608182-27A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-29A Custodial Office Sink Faucet	7/30/16 2:13 PM	8/6/2016	1608182-28A	COPPER	0.4 PPM	1.3 PPM
50-30A Main Office by Conference Room Sink Faucet	7/30/16 2:21 PM	8/6/2016	1608182-29A	COPPER	0.4 PPM	1.3 PPM
50-31A Student Store Sink Faucet	7/30/16 2:23 PM	8/6/2016	1608182-30A	COPPER	0.4 PPM	1.3 PPM
50-32A Hall by Student Store Drinking Fountain 5	7/30/16 2:26 PM	8/6/2016	1608182-31A	COPPER	0.3 PPM	1.3 PPM
50-33A Hall South Drinking Fountain 6	7/30/16 2:30 PM	8/6/2016	1608182-32A	COPPER	0.6 PPM	1.3 PPM
50-34A Room 111 Sink Faucet	7/30/16 2:31 PM	8/6/2016	1608182-33A	COPPER	0.5 PPM	1.3 PPM
50-35A Room 111 Drinking Fountain	7/30/16 2:31 PM	8/6/2016	1608182-34A	COPPER	0.7 PPM	1.3 PPM
50-36A Room 111/112 Work Room Sink Faucet	7/30/16 2:32 PM	8/6/2016	1608182-35A	COPPER	0.4 PPM	1.3 PPM
50-37A Room 112 Sink Faucet	7/30/16 2:34 PM	8/6/2016	1608182-36A	COPPER	0.3 PPM	1.3 PPM
50-38A Room 128 Sink Faucet 1	7/30/16 2:37 PM	8/6/2016	1608182-37A	COPPER	0.3 PPM	1.3 PPM
50-39A Room 128 Sink Faucet 2	7/30/16 2:38 PM	8/6/2016	1608182-38A	COPPER	0.5 PPM	1.3 PPM
50-40A Room 128 Sink Faucet 3	7/30/16 2:39 PM	8/6/2016	1608182-39A	COPPER	0.4 PPM	1.3 PPM
50-41A Room 128 Sink Faucet 4	7/30/16 2:39 PM	8/6/2016	1608182-40A	COPPER	0.3 PPM	1.3 PPM
50-42A Room 128 Sink Faucet 5	7/30/16 2:40 PM	8/6/2016	1608182-41A	COPPER	0.2 PPM	1.3 PPM
50-43A Room 128 Sink Faucet 6	7/30/16 2:40 PM	8/6/2016	1608182-42A	COPPER	0.2 PPM	1.3 PPM
50-44A Room 128 Sink Faucet 7	7/30/16 2:41 PM	8/6/2016	1608182-43A	COPPER	0.2 PPM	1.3 PPM
50-45A Hall South Near Room 113 Drinking Fountain 7	7/30/16 2:51 PM	8/6/2016	1608182-44A	COPPER	0.6 PPM	1.3 PPM
50-46A Girl's Locker Room Drinking Fountain (Left)	7/30/16 2:53 PM	8/6/2016	1608182-45A	COPPER	0.4 PPM	1.3 PPM
50-47A Girl's Locker Room Drinking Fountain (Right)	7/30/16 2:54 PM	8/6/2016	1608182-46A	COPPER	0.4 PPM	1.3 PPM
50-48A Gymnasium Southwest Side Drinking Fountain	7/30/16 2:58 PM	8/6/2016	1608182-47A	COPPER	0.2 PPM	1.3 PPM
50-49A Gymnasium Southeast Corner Drinking Fountain	7/30/16 3:02 PM	8/6/2016	1608182-48A	COPPER	0.3 PPM	1.3 PPM
50-50A Gymnasium Hall Drinking Fountain	7/30/16 2:58 PM	8/6/2016	1608182-49A	COPPER	0.2 PPM	1.3 PPM
50-51A Boy's Locker Room Drinking Fountain (Left)	7/30/16 3:06 PM	8/6/2016	1608182-50A	COPPER	0.1 PPM	1.3 PPM
50-52A Boy's Locker Room Drinking Fountain (Right)	7/30/16 3:07 PM	8/6/2016	1608182-51A	COPPER	0.1 PPM	1.3 PPM
50-53A Boy's Locker Room Back Wall Drinking Fountain	7/30/16 3:11 PM	8/6/2016	1608182-52A	COPPER	0.1 PPM	1.3 PPM
50-54A Team Locker Room Drinking Fountain (Left)	7/30/16 3:06 PM	8/6/2016	1608182-53A	COPPER	0.2 PPM	1.3 PPM
50-55A Team Locker Room Drinking Fountain (Right)	7/30/16 3:06 PM	8/6/2016	1608182-54A	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-56A Team Locker Room Drinking Fountain Back	7/30/16 3:11 PM	8/6/2016	1608182-55A	COPPER	0.5 PPM	1.3 PPM
50-57A Training Room Sink Faucet	7/30/16 3:15 PM	8/6/2016	1608182-56A	COPPER	0.1 PPM	1.3 PPM
50-58A 2nd Floor Hall Drinking Fountain 8	7/30/16 3:33 PM	8/6/2016	1608182-57A	COPPER	0.3 PPM	1.3 PPM
50-59A West Balcony Gymnasium Drinking Fountain	7/30/16 3:32 PM	8/6/2016	1608182-58A	COPPER	0.1 PPM	1.3 PPM
50-60A Hall Drinking Fountain 9	7/30/16 3:35 PM	8/6/2016	1608182-59A	COPPER	0.7 PPM	1.3 PPM
50-61A 2nd Floor Hall Southwest Corner Drinking Fountain 10	7/30/16 3:42 PM	8/6/2016	1608182-60A	COPPER	0.6 PPM	1.3 PPM
50-62A 2nd Floor Hall East Drinking Fountain 11	7/30/16 3:39 PM	8/6/2016	1608182-61A	COPPER	0.3 PPM	1.3 PPM
50-63A Room 234 Sink Faucet	7/30/16 3:40 PM	8/6/2016	1608182-62A	COPPER	0.2 PPM	1.3 PPM
50-64A Hall Northeast Drinking Fountain 12	7/30/16 3:43 PM	8/6/2016	1608182-63A	COPPER	0.2 PPM	1.3 PPM
50-65A Room 239 Sink Faucet	7/30/16 3:47 PM	8/6/2016	1608182-64A	COPPER	0.2 PPM	1.3 PPM
50-66A Room 251 Sink Faucet	7/30/16 3:47 PM	8/6/2016	1608182-65A	COPPER	0.2 PPM	1.3 PPM
50-67A Room 250 Sink Faucet	7/30/16 3:49 PM	8/6/2016	1608182-66A	COPPER	0.2 PPM	1.3 PPM
50-68A Room 240 Sink Faucet	7/30/16 3:49 PM	8/6/2016	1608182-67A	COPPER	0.5 PPM	1.3 PPM
50-69A Room 241 Sink Faucet	7/30/16 3:52 PM	8/6/2016	1608182-68A	COPPER	0.4 PPM	1.3 PPM
50-70A Room 242 Sink Faucet	7/30/16 3:54 PM	8/6/2016	1608182-69A	COPPER	0.2 PPM	1.3 PPM
50-71A Room 243 Sink Faucet	7/30/16 3:55 PM	8/6/2016	1608182-70A	COPPER	0.3 PPM	1.3 PPM
50-72A Room 244 Sink Faucet	7/30/16 3:58 PM	8/6/2016	1608182-71A	COPPER	0.3 PPM	1.3 PPM
50-73A 2nd Hall Drinking Fountain 13	7/30/16 4:00 PM	8/6/2016	1608182-72A	COPPER	0.3 PPM	1.3 PPM
50-74A 2nd Floor Hall Drinking Fountain 14	7/30/16 4:03 PM	8/6/2016	1608182-73A	COPPER	0.2 PPM	1.3 PPM
50-75A 2nd Floor Hall Drinking Fountain 15	7/30/16 4:03 PM	8/6/2016	1608182-74A	COPPER	0.6 PPM	1.3 PPM
50-76A 2nd Floor Hall Near Room 244 Drinking Fountain 16	7/30/16 3:57 PM	8/6/2016	1608182-75A	COPPER	0.3 PPM	1.3 PPM
50-77A Concession Stand Sink Faucet	7/30/16 4:20 PM	8/6/2016	1608182-76A	COPPER	0.3 PPM	1.3 PPM
50-78A Room B-3 Drinking Fountain	7/30/16 1:09 PM	8/6/2016	1608182-77A	COPPER	0.9 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
 Copper Water Sampling Results
 Flushed (B) Sample Data
 South Salem High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
50-04B Kitchen Center Sink Faucet	7/30/16 12:35 AM	8/24/2016	1608183-04A	COPPER	0.4 PPM	1.3 PPM
50-47B Girls' Locker Room Drinking Fountain (Right)	7/30/16 12:35 AM	8/24/2016	1608183-46A	COPPER	0.1 PPM	1.3 PPM
EPA Action Level for Copper in Schools is 1.3 PPM						
SKPS Action Level for Copper is 1.3 PPM						
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level						

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (C) Sample Data
South Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
50-04C Kitchen Center Sink Faucet	1/20/2017 5:17	1/23/2017	3128	COPPER	0.4 PPM	1.3 PPM
50-47C Girl's Locker Room Drinking Fountain (Right)	1/20/2017 5:30	1/23/2017	3129	COPPER	0.1 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level