

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Sprague High School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Tested For	Result		Action Level
051-01A	Hall Drinking Fountain 1	7/23/16 9:41	7/30/2016	1607A87-01A	COPPER	0.6	PPM	1.3 PPM
051-02A	Hall Drinking Fountain 2	7/23/16 9:43	7/30/2016	1607A87-02A	COPPER	0.7	PPM	1.3 PPM
051-03A	Preschool Room 7 Sink Faucet	7/23/16 9:47	7/30/2016	1607A87-03A	COPPER	0.6	PPM	1.3 PPM
051-04A	Preschool Room 5 Sink Faucet	7/23/16 9:50	7/30/2016	1607A87-04A	COPPER	0.3	PPM	1.3 PPM
051-05A	Room 3 Sink Faucet	7/23/16 9:54	7/30/2016	1607A87-05A	COPPER	0.4	PPM	1.3 PPM
051-06A	Room 1 Sink Faucet	7/23/16 9:58	7/30/2016	1607A87-06A	COPPER	0.4	PPM	1.3 PPM
051-07A	Hall Drinking Fountain 3	7/23/16 10:03	7/30/2016	1607A87-07A	COPPER	0.8	PPM	1.3 PPM
051-08A	Hall Drinking Fountain 4	7/23/16 10:05	7/30/2016	1607A87-08A	COPPER	0.6	PPM	1.3 PPM
051-09A	Library Break Room Sink Faucet	7/23/16 10:08	7/30/2016	1607A87-09A	COPPER	0.4	PPM	1.3 PPM
051-10A	Hall Drinking Fountain 5	7/23/16 10:13	7/30/2016	1607A87-10A	COPPER	0.5	PPM	1.3 PPM
051-11A	Hall Drinking Fountain 6	7/23/16 10:15	7/31/2016	1607A87-11A	COPPER	1	PPM	1.3 PPM
051-12A	Staff Lounge 157 Sink Faucet	7/23/16 10:20	7/30/2016	1607A87-12A	COPPER	0.3	PPM	1.3 PPM
051-13A	Hall Drinking Fountain 7	7/23/16 10:22	7/30/2016	1607A87-13A	COPPER	0.8	PPM	1.3 PPM
051-14A	Room 110/112 Break Area Sink Faucet	7/23/16 10:27	7/30/2016	1607A87-14A	COPPER	0.6	PPM	1.3 PPM
051-16A	Faculty Prep 129 Sink Faucet	7/23/16 10:30	7/30/2016	1607A87-15A	COPPER	0.6	PPM	1.3 PPM
051-17A	Hall Drinking Fountain 9	7/23/16 10:34	7/30/2016	1607A87-16A	COPPER	0.6	PPM	1.3 PPM
051-18A	Office Workroom Sink Faucet	7/23/16 10:39	7/30/2016	1607A87-17A	COPPER	0.4	PPM	1.3 PPM
051-19A	Health Sink Faucet	7/23/16 10:43	7/30/2016	1607A87-18A	COPPER	0.3	PPM	1.3 PPM
051-20A	Health Sink Faucet	7/23/16 10:45	7/30/2016	1607A87-19A	COPPER	0.3	PPM	1.3 PPM
051-21A	Drama 162 Sink Faucet	7/23/16 10:51	7/30/2016	1607A87-20A	COPPER	0.6	PPM	1.3 PPM
051-22A	Drama 162 Drinking Fountain	7/23/16 10:53	7/30/2016	1607A87-21A	COPPER	0.4	PPM	1.3 PPM
051-23A	Hall Drinking Fountain 10	7/23/16 10:56	7/30/2016	1607A87-22A	COPPER	0.6	PPM	1.3 PPM
051-24A	Hall Drinking Fountain 11	7/23/16 10:59	7/30/2016	1607A87-23A	COPPER	0.7	PPM	1.3 PPM
051-25A	Room 171 Sink Faucet	7/23/16 11:03	7/30/2016	1607A87-24A	COPPER	0.5	PPM	1.3 PPM
051-26A	Room 171 Drinking Fountain	7/23/16 11:05	7/30/2016	1607A87-25A	COPPER	0.5	PPM	1.3 PPM
051-27A	Band 175 Sink Faucet	7/23/16 11:08	7/30/2016	1607A87-26A	COPPER	0.4	PPM	1.3 PPM
051-28A	Band 175 Drinking Fountain	7/23/16 11:10	7/30/2016	1607A87-27A	COPPER	0.5	PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Sprague High School

051-29A	Hall Drinking Fountain 12	7/23/16 11:14	7/30/2016	1607A87-28A	COPPER	0.8 PPM	1.3 PPM
051-30A	Kitchen Ice Maker	7/23/16 11:18	7/30/2016	1607A87-29A	COPPER	<0.0 PPM	1.3 PPM
051-31A	Kitchen Food Prep	7/23/16 11:20	7/30/2016	1607A87-30A	COPPER	0.2 PPM	1.3 PPM
051-32A	Activities Gym Drinking Fountain	7/23/16 11:26	7/30/2016	1607A87-31A	COPPER	0.6 PPM	1.3 PPM
051-33A	Main Gym Drinking Fountain	7/23/16 11:29	7/30/2016	1607A87-32A	COPPER	0.4 PPM	1.3 PPM
051-34A	Hall Drinking Fountain 13	7/23/16 11:33	7/30/2016	1607A87-33A	COPPER	0.4 PPM	1.3 PPM
051-35A	Hall Drinking Fountain 14	7/23/16 11:35	7/30/2016	1607A87-34A	COPPER	0.7 PPM	1.3 PPM
051-36A	Training Room Ice Maker	7/23/16 11:38	7/30/2016	1607A87-35A	COPPER	<0.0 PPM	1.3 PPM
051-37A	Boys Locker Room Drinking Fountain 1	7/23/16 11:42	7/31/2016	1607A87-36A	COPPER	1.7 PPM	1.3 PPM
051-38A	Boys Locker Room Drinking Fountain 2	7/23/16 11:45	7/30/2016	1607A87-37A	COPPER	0.7 PPM	1.3 PPM
051-39A	Girls Locker Room Drinking Fountain 1	7/23/16 11:50	7/30/2016	1607A87-38A	COPPER	0.6 PPM	1.3 PPM
051-40A	Girls Locker Room Drinking Fountain 2	7/23/16 11:53	7/30/2016	1607A87-39A	COPPER	0.8 PPM	1.3 PPM
051-41A	Hall Drinking Fountain 15	7/23/16 11:57	7/30/2016	1607A87-40A	COPPER	0.5 PPM	1.3 PPM
051-42A	Hall Drinking Fountain 16	7/23/16 11:59	7/30/2016	1607A87-41A	COPPER	0.4 PPM	1.3 PPM
051-43A	Concessions Sink Faucet	7/23/16 12:03	7/30/2016	1607A87-42A	COPPER	0.4 PPM	1.3 PPM
051-44A	Health 17 Sink Faucet	7/23/16 12:07	7/30/2016	1607A87-43A	COPPER	0.3 PPM	1.3 PPM
051-45A	Room 18 Sink Faucet	7/23/16 12:10	7/30/2016	1607A87-44A	COPPER	0.3 PPM	1.3 PPM
051-46A	Hall Drinking Fountain 17	7/23/16 12:14	7/30/2016	1607A87-45A	COPPER	0.8 PPM	1.3 PPM
051-47A	Hall Drinking Fountain 18	7/23/16 12:16	7/30/2016	1607A87-46A	COPPER	0.7 PPM	1.3 PPM
051-49A	Stadium Concessions Sink Faucet 1	7/23/16 12:24	7/30/2016	1607A87-47A	COPPER	0.1 PPM	1.3 PPM
051-50A	Stadium Concessions Sink Faucet 2	7/23/16 12:27	7/30/2016	1607A87-48A	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Sprague High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
051-15A Hallway Drinking Fountain #8	9/22/2016 6:01	9/26/2016	57955	COPPER	1.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Sprague High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
051-51A Staff Rm 157 Refrigerator Water Dispenser	1/20/2017 5:00	1/23/2017	3125	COPPER	0.0 PPM	1.3 PPM
051-52A Staff Rm 157 Refrigerator Ice Dispenser	1/20/2017 5:01	1/23/2017	3126	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
Flushed (B) Sample Data
Sprague High School

Sample Identification # and Location		Date/Time Collected	Date Analyzed	Container ID	Tested For	Result		Action Level
051-22B	Drama 162 Drinking Fountain	7/23/2016	8/14/2016	1607A88-21A	COPPER	0.4	PPM	1.3 PPM
051-37B	Boys Locker Room Drinking Fountain 1	7/23/2016	8/15/2016	1607A88-34A	COPPER	2.0	PPM	1.3 PPM
EPA Action Level for Copper in Schools is 1.3 PPM								
SKPS Action Level for Copper is 1.3 PPM								
Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level								