

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Results  
Sprague High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level	
051-01A	Hall Drinking Fountain 1	7/23/16 9:41	7/30/2016	1607A87-01A	LEAD	2 PPB	15 PPB
051-02A	Hall Drinking Fountain 2	7/23/16 9:43	7/30/2016	1607A87-02A	LEAD	2 PPB	15 PPB
051-03A	Preschool Room 7 Sink Faucet	7/23/16 9:47	7/30/2016	1607A87-03A	LEAD	3 PPB	15 PPB
051-04A	Preschool Room 5 Sink Faucet	7/23/16 9:50	7/30/2016	1607A87-04A	LEAD	3 PPB	15 PPB
051-05A	Room 3 Sink Faucet	7/23/16 9:54	7/30/2016	1607A87-05A	LEAD	4 PPB	15 PPB
051-06A	Room 1 Sink Faucet	7/23/16 9:58	7/30/2016	1607A87-06A	LEAD	<1.0 PPB	15 PPB
051-07A	Hall Drinking Fountain 3	7/23/16 10:03	7/30/2016	1607A87-07A	LEAD	3 PPB	15 PPB
051-08A	Hall Drinking Fountain 4	7/23/16 10:05	7/30/2016	1607A87-08A	LEAD	<1.0 PPB	15 PPB
051-09A	Library Break Room Sink Faucet	7/23/16 10:08	7/30/2016	1607A87-09A	LEAD	4 PPB	15 PPB
051-10A	Hall Drinking Fountain 5	7/23/16 10:13	7/30/2016	1607A87-10A	LEAD	7 PPB	15 PPB
051-11A	Hall Drinking Fountain 6	7/23/16 10:15	7/30/2016	1607A87-11A	LEAD	2 PPB	15 PPB
051-12A	Staff Lounge 157 Sink Faucet	7/23/16 10:20	7/30/2016	1607A87-12A	LEAD	2 PPB	15 PPB
051-13A	Hall Drinking Fountain 7	7/23/16 10:22	7/30/2016	1607A87-13A	LEAD	4 PPB	15 PPB
051-14A	Room 110/112 Break Area Sink Faucet	7/23/16 10:27	7/30/2016	1607A87-14A	LEAD	3 PPB	15 PPB
051-16A	Faculty Prep 129 Sink Faucet	7/23/16 10:30	7/30/2016	1607A87-15A	LEAD	1 PPB	15 PPB
051-17A	Hall Drinking Fountain 9	7/23/16 10:34	7/30/2016	1607A87-16A	LEAD	<1.0 PPB	15 PPB
051-18A	Office Workroom Sink Faucet	7/23/16 10:39	7/30/2016	1607A87-17A	LEAD	2 PPB	15 PPB
051-19A	Health Sink Faucet	7/23/16 10:43	7/30/2016	1607A87-18A	LEAD	2 PPB	15 PPB
051-20A	Health Sink Faucet	7/23/16 10:45	7/30/2016	1607A87-19A	LEAD	3 PPB	15 PPB
051-21A	Drama 162 Sink Faucet	7/23/16 10:51	7/30/2016	1607A87-20A	LEAD	6 PPB	15 PPB
051-22A	Drama 162 Drinking Fountain	7/23/16 10:53	7/30/2016	1607A87-21A	LEAD	24 PPB	15 PPB
051-23A	Hall Drinking Fountain 10	7/23/16 10:56	7/30/2016	1607A87-22A	LEAD	1 PPB	15 PPB
051-24A	Hall Drinking Fountain 11	7/23/16 10:59	7/30/2016	1607A87-23A	LEAD	<1.0 PPB	15 PPB
051-25A	Room 171 Sink Faucet	7/23/16 11:03	7/30/2016	1607A87-24A	LEAD	<1.0 PPB	15 PPB
051-26A	Room 171 Drinking Fountain	7/23/16 11:05	7/30/2016	1607A87-25A	LEAD	6 PPB	15 PPB
051-27A	Band 175 Sink Faucet	7/23/16 11:08	7/30/2016	1607A87-26A	LEAD	<1.0 PPB	15 PPB
051-28A	Band 175 Drinking Fountain	7/23/16 11:10	7/30/2016	1607A87-27A	LEAD	4 PPB	15 PPB
051-29A	Hall Drinking Fountain 12	7/23/16 11:14	7/30/2016	1607A87-28A	LEAD	<1.0 PPB	15 PPB
051-30A	Kitchen Ice Maker	7/23/16 11:18	7/30/2016	1607A87-29A	LEAD	<1.0 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Results  
Sprague High School

051-31A	Kitchen Food Prep Sink Faucet	7/23/16 11:20	7/30/2016	1607A87-30A	LEAD	2	PPB	15 PPB
051-32A	Activities Gymnasium Drinking Fountain	7/23/16 11:26	7/30/2016	1607A87-31A	LEAD	1	PPB	15 PPB
051-33A	Main Gymnasium Drinking Fountain	7/23/16 11:29	7/30/2016	1607A87-32A	LEAD	<1.0	PPB	15 PPB
051-34A	Hall Drinking Fountain 13	7/23/16 11:33	7/30/2016	1607A87-33A	LEAD	2	PPB	15 PPB
051-35A	Hall Drinking Fountain 14	7/23/16 11:35	7/30/2016	1607A87-34A	LEAD	1	PPB	15 PPB
051-36A	Training Room Ice Maker	7/23/16 11:38	7/30/2016	1607A87-35A	LEAD	<1.0	PPB	15 PPB
051-37A	Boys Locker Room Drinking Fountain 1	7/23/16 11:42	7/30/2016	1607A87-36A	LEAD	38	PPB	15 PPB
051-38A	Boys Locker Room Drinking Fountain 2	7/23/16 11:45	7/30/2016	1607A87-37A	LEAD	2	PPB	15 PPB
051-39A	Girls Locker Room Drinking Fountain 1	7/23/16 11:50	7/30/2016	1607A87-38A	LEAD	2	PPB	15 PPB
051-40A	Girls Locker Room Drinking Fountain 2	7/23/16 11:53	7/30/2016	1607A87-39A	LEAD	6	PPB	15 PPB
051-41A	Hall Drinking Fountain 15	7/23/16 11:57	7/30/2016	1607A87-40A	LEAD	<1.0	PPB	15 PPB
051-42A	Hall Drinking Fountain 16	7/23/16 11:59	7/30/2016	1607A87-41A	LEAD	<1.0	PPB	15 PPB
051-43A	Concessions Sink Faucet	7/23/16 12:03	7/30/2016	1607A87-42A	LEAD	3	PPB	15 PPB
051-44A	Health 17 Sink Faucet	7/23/16 12:07	7/30/2016	1607A87-43A	LEAD	3	PPB	15 PPB
051-45A	Room 18 Sink Faucet	7/23/16 12:10	7/30/2016	1607A87-44A	LEAD	2	PPB	15 PPB
051-46A	Hall Drinking Fountain 17	7/23/16 12:14	7/30/2016	1607A87-45A	LEAD	<1.0	PPB	15 PPB
051-47A	Hall Drinking Fountain 18	7/23/16 12:16	7/30/2016	1607A87-46A	LEAD	1	PPB	15 PPB
051-49A	Stadium Concessions Sink Faucet 1	7/23/16 12:24	7/30/2016	1607A87-47A	LEAD	3	PPB	15 PPB
051-50A	Stadium Concessions Sink Faucet 2	7/23/16 12:27	7/30/2016	1607A87-48A	LEAD	7	PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Sprague High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
051-15A Hallway Drinking Fountain #8	9/22/2016 6:01	9/26/2016	57955	LEAD	2 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

---

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Sprague High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
051-51A Staff Rm 157 Refrigerator Water Dispenser	1/20/2017 5:00	1/23/2017	3125	LEAD	<1.0 PPB	15 PPB
051-52A Staff Rm 157 Refrigerator Ice Dispenser	1/20/2017 5:01	1/23/2017	3126	LEAD	<1.0 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 Flushed (B) Sample Data  
 Sprague High School

Sample Identification # and Location	Date/Time Collected	Date Analyzed	Container ID	Tested For	Result	Action Level
051-22B Drama 162 Drinking Fountain	7/23/2016	8/14/2016	1607A88-21A	LEAD	8 PPB	15 PPB
051-37B Boys Locker Room Drinking Fountain 1	7/23/2016	8/14/2016	1607A88-34A	LEAD	<1.0 PPB	15 PPB
EPA Action Level for Lead in Schools is 20 PPB						
SKPS Action Level for Lead is 15 PPB						
<b>Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level</b>						