

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Straub Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
053-01A Main Gymnasium Drinking Fountain	7/22/2016 6:49	8/2/2016	44256	COPPER	0.6 PPM	1.3 PPM
053-02A Main Gymnasium Drinking Fountain	7/22/2016 6:51	8/2/2016	44257	COPPER	0.6 PPM	1.3 PPM
053-03A Auxillary Gymnasium Drinking Fountain	7/22/2016 6:54	8/2/2016	44258	COPPER	0.9 PPM	1.3 PPM
053-04A Auxillary Gymnasium Drinking Fountain	7/22/2016 6:56	8/2/2016	44259	COPPER	0.9 PPM	1.3 PPM
053-05A Student Activities 151 Sink Faucet	7/22/2016 7:00	8/2/2016	44260	COPPER	0.5 PPM	1.3 PPM
053-06A Student Store 153 Sink Faucet	7/22/2016 7:02	8/2/2016	44261	COPPER	0.4 PPM	1.3 PPM
053-07A Cafeteria Drinking Fountain	7/22/2016 7:05	8/2/2016	44262	COPPER	0.6 PPM	1.3 PPM
053-08A Cafeteria Drinking Fountain	7/22/2016 7:07	8/2/2016	44263	COPPER	0.5 PPM	1.3 PPM
053-09A Kitchen Ice Maker	7/22/2016 7:10	8/2/2016	44264	COPPER	0.0 PPM	1.3 PPM
053-10A Kitchen Food Prep Sink Faucet	7/22/2016 7:12	8/2/2016	44265	COPPER	0.1 PPM	1.3 PPM
053-11A Band 129 Drinking Fountain	7/22/2016 7:15	8/2/2016	44266	COPPER	0.8 PPM	1.3 PPM
053-12A Orchestra 122 Drinking Fountain	7/22/2016 7:18	8/2/2016	44267	COPPER	0.7 PPM	1.3 PPM
053-13A Choir 120 Drinking Fountain	7/22/2016 7:21	8/2/2016	44268	COPPER	0.7 PPM	1.3 PPM
053-14A Computer Lab 118 Drinking Fountain	7/22/2016 7:24	8/2/2016	44269	COPPER	0.6 PPM	1.3 PPM
053-15A Computer Lab 118 Sink Faucet	7/22/2016 7:26	8/2/2016	44270	COPPER	0.5 PPM	1.3 PPM
053-16A Computer Lab117 Sink Faucet	7/22/2016 7:29	8/2/2016	44271	COPPER	0.5 PPM	1.3 PPM
053-17A Computer Lab 117 Drinking Fountain	7/22/2016 7:31	8/2/2016	44272	COPPER	0.3 PPM	1.3 PPM
053-18A PLC 107 Ice Maker (Refrigerator)	7/22/2016 7:34	8/5/2016	44273	COPPER	1.8 PPM	1.3 PPM
053-19A PLC 107 Sink Faucet	7/22/2016 7:35	8/2/2016	44274	COPPER	0.6 PPM	1.3 PPM
053-20A Classroom 104 Sink Faucet	7/22/2016 7:38	8/2/2016	44275	COPPER	0.6 PPM	1.3 PPM
053-21A Classroom 104 Drinking Fountain	7/22/2016 7:40	8/2/2016	44276	COPPER	0.6 PPM	1.3 PPM
053-22A Classroom 105 Drinking Fountain	7/22/2016 7:44	8/2/2016	44277	COPPER	0.6 PPM	1.3 PPM
053-23A Classroom 105 Sink Faucet	7/22/2016 7:46	8/2/2016	44278	COPPER	0.5 PPM	1.3 PPM
053-24A Classroom 102 Drinking Fountain	7/22/2016 7:49	8/2/2016	44279	COPPER	0.7 PPM	1.3 PPM
053-25A Classroom 102 Sink Faucet	7/22/2016 7:51	8/2/2016	44280	COPPER	0.6 PPM	1.3 PPM
053-26A Classroom 101 Sink Faucet	7/22/2016 7:54	8/2/2016	44281	COPPER	0.7 PPM	1.3 PPM
053-27A Classroom 101 Drinking Fountain	7/22/2016 7:56	8/2/2016	44282	COPPER	0.5 PPM	1.3 PPM
053-28A Classroom 103 Sink Faucet	7/22/2016 7:59	8/2/2016	44283	COPPER	0.6 PPM	1.3 PPM
053-29A Classroom 103 Drinking Fountain	7/22/2016 8:01	8/2/2016	44284	COPPER	0.7 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Straub Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
053-30A Classroom 201 Drinking Fountain	7/22/2016 8:04	8/2/2016	44285	COPPER	0.7 PPM	1.3 PPM
053-31A Classroom 201 Sink faucet	7/22/2016 8:06	8/2/2016	44286	COPPER	0.6 PPM	1.3 PPM
053-32A Classroom 203 Sink Faucet	7/22/2016 8:09	8/2/2016	44287	COPPER	0.6 PPM	1.3 PPM
053-33A Classroom 203 Drinking Fountain	7/22/2016 8:11	8/2/2016	44288	COPPER	0.5 PPM	1.3 PPM
053-34A Classroom 202 Drinking Fountain	7/22/2016 8:15	8/2/2016	44289	COPPER	0.5 PPM	1.3 PPM
053-35A Classroom 202 Sink Faucet	7/22/2016 8:17	8/2/2016	44290	COPPER	0.5 PPM	1.3 PPM
053-36A Classroom 204 Sink Faucet	7/22/2016 8:20	8/2/2016	44291	COPPER	0.4 PPM	1.3 PPM
053-37A Classroom 204 Drinking fountain	7/22/2016 8:22	8/2/2016	44292	COPPER	0.5 PPM	1.3 PPM
053-38A Classroom 205 Drinking Fountain	7/22/2016 8:25	8/2/2016	44293	COPPER	0.5 PPM	1.3 PPM
053-39A Classroom 205 Sink faucet	7/22/2016 8:27	8/2/2016	44294	COPPER	0.4 PPM	1.3 PPM
053-40A PLC 207 Ice maker (Refrigerator)	7/22/2016 8:30	8/2/2016	44295	COPPER	0.8 PPM	1.3 PPM
053-41A PLC 207 Sink Faucet	7/22/2016 8:31	8/2/2016	44296	COPPER	0.4 PPM	1.3 PPM
053-42A Classroom 217 Drinking Fountain	7/22/2016 8:35	8/2/2016	44297	COPPER	0.6 PPM	1.3 PPM
053-43A Classroom 217 Sink Faucet	7/22/2016 8:37	8/2/2016	44298	COPPER	0.5 PPM	1.3 PPM
053-44A Classroom 222 Sink Faucet	7/22/2016 8:40	8/2/2016	44299	COPPER	0.6 PPM	1.3 PPM
053-45A Classroom 222 Drinking Fountain	7/22/2016 8:42	8/2/2016	44300	COPPER	0.5 PPM	1.3 PPM
053-46A Nurse Ice maker (Refrigerator)	7/22/2016 8:46	8/2/2016	44301	COPPER	0.8 PPM	1.3 PPM
053-47A Office Sink Faucet	7/22/2016 8:49	8/2/2016	44302	COPPER	0.4 PPM	1.3 PPM
053-48A Industrial 257 Drinking Fountain	7/22/2016 8:53	8/2/2016	44303	COPPER	0.7 PPM	1.3 PPM
053-49A Industrial 257 Sink faucet	7/22/2016 8:55	8/2/2016	44304	COPPER	0.5 PPM	1.3 PPM
053-50A Library Drinking Fountain	7/22/2016 9:00	8/2/2016	44305	COPPER	0.8 PPM	1.3 PPM
053-51A Library Drinking Fountain	7/22/2016 9:02	8/2/2016	44306	COPPER	0.8 PPM	1.3 PPM
053-52A Classroom 337 Sink Faucet	7/22/2016 9:06	8/2/2016	44307	COPPER	0.6 PPM	1.3 PPM
053-53A Classroom 337 Drinking Fountain	7/22/2016 9:08	8/2/2016	44308	COPPER	0.5 PPM	1.3 PPM
053-54A Classroom 336 Drinking Fountain	7/22/2016 9:11	8/2/2016	44309	COPPER	0.7 PPM	1.3 PPM
053-55A Classroom 336 Sink Faucet	7/22/2016 9:13	8/2/2016	44310	COPPER	0.6 PPM	1.3 PPM
053-56A Home Economics 325 Sink Faucet #1	7/22/2016 9:18	8/2/2016	44311	COPPER	0.5 PPM	1.3 PPM
053-57A Home Economics 325 Sink Faucet #2	7/22/2016 9:20	8/2/2016	44312	COPPER	0.4 PPM	1.3 PPM
053-58A Home Economics 325 Sink Faucet #3	7/22/2016 9:22	8/2/2016	44313	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Straub Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
053-59A Home Economics 325 Sink Faucet #4	7/22/2016 9:24	8/2/2016	44314	COPPER	0.6 PPM	1.3 PPM
053-60A Home Economics 325 Sink Faucet #5	7/22/2016 9:26	8/2/2016	44315	COPPER	0.4 PPM	1.3 PPM
053-61A Home Economics 325 Sink Faucet #6	7/22/2016 9:28	8/2/2016	44316	COPPER	0.4 PPM	1.3 PPM
053-62A Home Economics 325 Sink Faucet #7	7/22/2016 9:30	8/2/2016	44317	COPPER	0.4 PPM	1.3 PPM
053-63A Sewing 322 Sink Faucet	7/22/2016 9:34	8/2/2016	44318	COPPER	0.5 PPM	1.3 PPM
053-64A Sewing 322 Drinking Fountain	7/22/2016 9:36	8/2/2016	44319	COPPER	0.7 PPM	1.3 PPM
053-65A Classroom 319 Drinking Fountain	7/22/2016 9:40	8/2/2016	44320	COPPER	0.5 PPM	1.3 PPM
053-66A Classroom 319 Sink Faucet	7/22/2016 9:42	8/2/2016	44321	COPPER	0.5 PPM	1.3 PPM
053-67A Classroom 317 Drinking Fountain	7/22/2016 9:46	8/2/2016	44322	COPPER	0.4 PPM	1.3 PPM
053-68A Classroom 317 Sink Faucet	7/22/2016 9:48	8/2/2016	44323	COPPER	0.4 PPM	1.3 PPM
053-69A PLC 107 Ice Maker	7/22/2016 9:50	8/5/2016	44324	COPPER	1.1 PPM	1.3 PPM
053-70A PLC 107 Sink Faucet	7/22/2016 9:52	8/2/2016	44325	COPPER	0.5 PPM	1.3 PPM
053-71A Classroom 304 Sink Faucet	7/22/2016 9:55	8/2/2016	44326	COPPER	0.6 PPM	1.3 PPM
053-72A Classroom 304 Drinking Fountain	7/22/2016 9:57	8/2/2016	44327	COPPER	0.5 PPM	1.3 PPM
053-73A Classroom 305 Drinking Fountain	7/22/2016 10:00	8/2/2016	44328	COPPER	0.4 PPM	1.3 PPM
053-74A Classroom 305 Sink Faucet	7/22/2016 10:02	8/2/2016	44329	COPPER	0.4 PPM	1.3 PPM
053-75A Classroom 302 Drinking Fountain	7/22/2016 10:05	8/2/2016	44330	COPPER	0.4 PPM	1.3 PPM
053-76A Classroom 302 Sink Faucet	7/22/2016 10:07	8/2/2016	44331	COPPER	0.4 PPM	1.3 PPM
053-77A Classroom 303 Sink Faucet	7/22/2016 10:11	8/2/2016	44332	COPPER	0.5 PPM	1.3 PPM
053-78A Classroom 303 Drinking Fountain	7/22/2016 10:13	8/2/2016	44333	COPPER	0.3 PPM	1.3 PPM
053-79A Classroom 301 Sink Faucet	7/22/2016 10:17	8/5/2016	44334	COPPER	0.3 PPM	1.3 PPM
053-80A Classroom 301 Drinking Fountain	7/22/2016 10:19	8/5/2016	44335	COPPER	0.3 PPM	1.3 PPM
053-81A Room 236 Sink Faucet	7/22/2016 8:51	8/5/2016	44336	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level