

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Straub Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
053-01A Main Gymnasium Drinking Fountain	7/22/2016 6:49	8/2/2016	44256	LEAD	<1 PPB	15 PPB
053-02A Main Gymnasium Drinking Fountain	7/22/2016 6:51	8/2/2016	44257	LEAD	<1 PPB	15 PPB
053-03A Auxillary Gymnasium Drinking Fountain	7/22/2016 6:54	8/2/2016	44258	LEAD	<1 PPB	15 PPB
053-04A Auxillary Gymnasium Drinking Fountain	7/22/2016 6:56	8/2/2016	44259	LEAD	<1 PPB	15 PPB
053-05A Student Activities 151 Sink Faucet	7/22/2016 7:00	8/2/2016	44260	LEAD	1 PPB	15 PPB
053-06A Student Store 153 Sink Faucet	7/22/2016 7:02	8/2/2016	44261	LEAD	4 PPB	15 PPB
053-07A Cafeteria Drinking Fountain	7/22/2016 7:05	8/2/2016	44262	LEAD	<1 PPB	15 PPB
053-08A Cafeteria Drinking Fountain	7/22/2016 7:07	8/2/2016	44263	LEAD	<1 PPB	15 PPB
053-09A Kitchen Ice Maker	7/22/2016 7:10	8/2/2016	44264	LEAD	<1 PPB	15 PPB
053-10A Kitchen Food Prep Sink Faucet	7/22/2016 7:12	8/2/2016	44265	LEAD	<1 PPB	15 PPB
053-11A Band 129 Drinking Fountain	7/22/2016 7:15	8/2/2016	44266	LEAD	<1 PPB	15 PPB
053-12A Orchestra 122 Drinking Fountain	7/22/2016 7:18	8/2/2016	44267	LEAD	<1 PPB	15 PPB
053-13A Choir 120 Drinking Fountain	7/22/2016 7:21	8/2/2016	44268	LEAD	<1 PPB	15 PPB
053-14A Computer Lab 118 Drinking Fountain	7/22/2016 7:24	8/2/2016	44269	LEAD	<1 PPB	15 PPB
053-15A Computer Lab 118 Sink Faucet	7/22/2016 7:26	8/2/2016	44270	LEAD	6 PPB	15 PPB
053-16A Computer Lab117 Sink Faucet	7/22/2016 7:29	8/2/2016	44271	LEAD	8 PPB	15 PPB
053-17A Computer Lab 117 Drinking Fountain	7/22/2016 7:31	8/2/2016	44272	LEAD	<1 PPB	15 PPB
053-18A PLC 107 Ice Maker (Refrigerator)	7/22/2016 7:34	8/5/2016	44273	LEAD	4 PPB	15 PPB
053-19A PLC 107 Sink Faucet	7/22/2016 7:35	8/2/2016	44274	LEAD	2 PPB	15 PPB
053-20A Classroom 104 Sink Faucet	7/22/2016 7:38	8/2/2016	44275	LEAD	2 PPB	15 PPB
053-21A Classroom 104 Drinking Fountain	7/22/2016 7:40	8/2/2016	44276	LEAD	<1 PPB	15 PPB
053-22A Classroom 105 Drinking Fountain	7/22/2016 7:44	8/2/2016	44277	LEAD	<1 PPB	15 PPB
053-23A Classroom 105 Sink Faucet	7/22/2016 7:46	8/2/2016	44278	LEAD	1 PPB	15 PPB
053-24A Classroom 102 Drinking Fountain	7/22/2016 7:49	8/2/2016	44279	LEAD	<1 PPB	15 PPB
053-25A Classroom 102 Sink Faucet	7/22/2016 7:51	8/2/2016	44280	LEAD	1 PPB	15 PPB
053-26A Classroom 101 Sink Faucet	7/22/2016 7:54	8/2/2016	44281	LEAD	<1 PPB	15 PPB
053-27A Classroom 101 Drinking Fountain	7/22/2016 7:56	8/2/2016	44282	LEAD	2 PPB	15 PPB
053-28A Classroom 103 Sink Faucet	7/22/2016 7:59	8/2/2016	44283	LEAD	<1 PPB	15 PPB
053-29A Classroom 103 Drinking Fountain	7/22/2016 8:01	8/2/2016	44284	LEAD	<1 PPB	15 PPB
053-30A Classroom 201 Drinking Fountain	7/22/2016 8:04	8/2/2016	44285	LEAD	<1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Straub Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
053-31A Classroom 201 Sink faucet	7/22/2016 8:06	8/2/2016	44286	LEAD	1 PPB	15 PPB
053-32A Classroom 203 Sink Faucet	7/22/2016 8:09	8/2/2016	44287	LEAD	2 PPB	15 PPB
053-33A Classroom 203 Drinking Fountain	7/22/2016 8:11	8/2/2016	44288	LEAD	<1 PPB	15 PPB
053-34A Classroom 202 Drinking Fountain	7/22/2016 8:15	8/2/2016	44289	LEAD	<1 PPB	15 PPB
053-35A Classroom 202 Sink Faucet	7/22/2016 8:17	8/2/2016	44290	LEAD	3 PPB	15 PPB
053-36A Classroom 204 Sink Faucet	7/22/2016 8:20	8/2/2016	44291	LEAD	1 PPB	15 PPB
053-37A Classroom 204 Drinking fountain	7/22/2016 8:22	8/2/2016	44292	LEAD	<1 PPB	15 PPB
053-38A Classroom 205 Drinking Fountain	7/22/2016 8:25	8/2/2016	44293	LEAD	<1 PPB	15 PPB
053-39A Classroom 205 Sink faucet	7/22/2016 8:27	8/2/2016	44294	LEAD	2 PPB	15 PPB
053-40A PLC 207 Ice maker (Refrigerator)	7/22/2016 8:30	8/2/2016	44295	LEAD	<1 PPB	15 PPB
053-41A PLC 207 Sink Faucet	7/22/2016 8:31	8/2/2016	44296	LEAD	1 PPB	15 PPB
053-42A Classroom 217 Drinking Fountain	7/22/2016 8:35	8/2/2016	44297	LEAD	<1 PPB	15 PPB
053-43A Classroom 217 Sink Faucet	7/22/2016 8:37	8/2/2016	44298	LEAD	<1 PPB	15 PPB
053-44A Classroom 222 Sink Faucet	7/22/2016 8:40	8/2/2016	44299	LEAD	2 PPB	15 PPB
053-45A Classroom 222 Drinking Fountain	7/22/2016 8:42	8/2/2016	44300	LEAD	<1 PPB	15 PPB
053-46A Nurse Ice maker (Refrigerator)	7/22/2016 8:46	8/2/2016	44301	LEAD	<1 PPB	15 PPB
053-47A Office Sink Faucet	7/22/2016 8:49	8/2/2016	44302	LEAD	2 PPB	15 PPB
053-48A Industrial 257 Drinking Fountain	7/22/2016 8:53	8/2/2016	44303	LEAD	<1 PPB	15 PPB
053-49A Industrial 257 Sink faucet	7/22/2016 8:55	8/2/2016	44304	LEAD	<1 PPB	15 PPB
053-50A Library Drinking Fountain	7/22/2016 9:00	8/2/2016	44305	LEAD	<1 PPB	15 PPB
053-51A Library Drinking Fountain	7/22/2016 9:02	8/2/2016	44306	LEAD	<1 PPB	15 PPB
053-52A Classroom 337 Sink Faucet	7/22/2016 9:06	8/2/2016	44307	LEAD	<1 PPB	15 PPB
053-53A Classroom 337 Drinking Fountain	7/22/2016 9:08	8/2/2016	44308	LEAD	<1 PPB	15 PPB
053-54A Classroom 336 Drinking Fountain	7/22/2016 9:11	8/2/2016	44309	LEAD	<1 PPB	15 PPB
053-55A Classroom 336 Sink Faucet	7/22/2016 9:13	8/2/2016	44310	LEAD	1 PPB	15 PPB
053-56A Home Economics 325 Sink Faucet #1	7/22/2016 9:18	8/2/2016	44311	LEAD	<1 PPB	15 PPB
053-57A Home Economics 325 Sink Faucet #2	7/22/2016 9:20	8/2/2016	44312	LEAD	2 PPB	15 PPB
053-58A Home Economics 325 Sink Faucet #3	7/22/2016 9:22	8/2/2016	44313	LEAD	1 PPB	15 PPB
053-59A Home Economics 325 Sink Faucet #4	7/22/2016 9:24	8/2/2016	44314	LEAD	5 PPB	15 PPB
053-60A Home Economics 325 Sink Faucet #5	7/22/2016 9:26	8/2/2016	44315	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Straub Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
053-61A Home Economics 325 Sink Faucet #6	7/22/2016 9:28	8/2/2016	44316	LEAD	1 PPB	15 PPB
053-62A Home Economics 325 Sink Faucet #7	7/22/2016 9:30	8/2/2016	44317	LEAD	1 PPB	15 PPB
053-63A Sewing 322 Sink Faucet	7/22/2016 9:34	8/2/2016	44318	LEAD	4 PPB	15 PPB
053-64A Sewing 322 Drinking Fountain	7/22/2016 9:36	8/2/2016	44319	LEAD	<1 PPB	15 PPB
053-65A Classroom 319 Drinking Fountain	7/22/2016 9:40	8/2/2016	44320	LEAD	<1 PPB	15 PPB
053-66A Classroom 319 Sink Faucet	7/22/2016 9:42	8/2/2016	44321	LEAD	2 PPB	15 PPB
053-67A Classroom 317 Drinking Fountain	7/22/2016 9:46	8/2/2016	44322	LEAD	2 PPB	15 PPB
053-68A Classroom 317 Sink Faucet	7/22/2016 9:48	8/2/2016	44323	LEAD	1 PPB	15 PPB
053-69A PLC 107 Ice Maker	7/22/2016 9:50	8/5/2016	44324	LEAD	<1 PPB	15 PPB
053-70A PLC 107 Sink Faucet	7/22/2016 9:52	8/2/2016	44325	LEAD	2 PPB	15 PPB
053-71A Classroom 304 Sink Faucet	7/22/2016 9:55	8/2/2016	44326	LEAD	4 PPB	15 PPB
053-72A Classroom 304 Drinking Fountain	7/22/2016 9:57	8/2/2016	44327	LEAD	<1 PPB	15 PPB
053-73A Classroom 305 Drinking Fountain	7/22/2016 10:00	8/2/2016	44328	LEAD	<1 PPB	15 PPB
053-74A Classroom 305 Sink Faucet	7/22/2016 10:02	8/2/2016	44329	LEAD	<1 PPB	15 PPB
053-75A Classroom 302 Drinking Fountain	7/22/2016 10:05	8/2/2016	44330	LEAD	<1 PPB	15 PPB
053-76A Classroom 302 Sink Faucet	7/22/2016 10:07	8/2/2016	44331	LEAD	<1 PPB	15 PPB
053-77A Classroom 303 Sink Faucet	7/22/2016 10:11	8/2/2016	44332	LEAD	<1 PPB	15 PPB
053-78A Classroom 303 Drinking Fountain	7/22/2016 10:13	8/2/2016	44333	LEAD	<1 PPB	15 PPB
053-79A Classroom 301 Sink Faucet	7/22/2016 10:17	8/5/2016	44334	LEAD	<1 PPB	15 PPB
053-80A Classroom 301 Drinking Fountain	7/22/2016 10:19	8/5/2016	44335	LEAD	<1 PPB	15 PPB
053-81A Room 236 Sink Faucet	7/22/2016 8:51	8/5/2016	44336	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level