

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Sumpter Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
054-01A Gymnasium Drinking Fountain	7/29/16 8:52	8/5/16 13:06	608012801	LEAD	1 PPB	15 PPB
054-02A Hallway Drinking Fountain 1	7/29/16 8:54	8/5/16 13:06	608012802	LEAD	1 PPB	15 PPB
054-03A Store Room Sink Faucet	7/29/16 8:59	8/5/16 13:06	608012803	LEAD	21 PPB	15 PPB
054-04A Music Room Sink Faucet	7/29/16 9:02	8/5/16 13:06	608012804	LEAD	22 PPB	15 PPB
054-05A Music Room Drinking Fountain	7/29/16 9:02	8/5/16 13:06	608012805	LEAD	1 PPB	15 PPB
054-06A Hallway Drinking Fountain 2	7/29/16 9:07	8/5/16 13:06	608012806	LEAD	7 PPB	15 PPB
054-07A Kitchen Food Prep Sink Faucet	7/29/16 9:09	8/5/16 13:06	608012807	LEAD	8 PPB	15 PPB
054-08A Faculty Lounge Sink Faucet	7/29/16 9:13	8/5/16 13:06	608012808	LEAD	2 PPB	15 PPB
054-09A Classroom A7 Sink Faucet	7/29/16 9:15	8/5/16 13:06	608012809	LEAD	8 PPB	15 PPB
054-10A Boys Bathroom Drinking Fountain	7/29/16 9:17	8/5/16 13:06	608012810	LEAD	< 1 PPB	15 PPB
054-11A Classroom A1 Sink Faucet	7/29/16 9:20	8/5/16 13:07	608012811	LEAD	6 PPB	15 PPB
054-12A Classroom A1 Drinking Fountain	7/29/16 9:20	8/5/16 13:07	608012812	LEAD	2 PPB	15 PPB
054-13A Classroom A2 Sink Faucet	7/29/16 9:24	8/5/16 13:07	608012813	LEAD	4 PPB	15 PPB
054-14A Classroom A2 Drinking Fountain	7/29/16 9:24	8/5/16 13:07	608012814	LEAD	1 PPB	15 PPB
054-15A Classroom A3 Sink Faucet	7/29/16 9:28	8/5/16 13:07	608012815	LEAD	5 PPB	15 PPB
054-16A Classroom A3 Drinking Fountain	7/29/16 9:28	8/5/16 13:07	608012816	LEAD	1 PPB	15 PPB
054-17A Classroom A4 Sink Faucet	7/29/16 9:33	8/5/16 13:07	608012817	LEAD	4 PPB	15 PPB
054-18A Classroom A4 Drinking Fountain	7/29/16 9:33	8/5/16 13:08	608012818	LEAD	2 PPB	15 PPB
054-19A Classroom A5 Sink Faucet	7/29/16 9:37	8/5/16 13:08	608012819	LEAD	2 PPB	15 PPB
054-20A Classroom A5 Drinking Fountain	7/29/16 9:37	8/5/16 13:08	608012820	LEAD	2 PPB	15 PPB
054-21A Classroom A6 Sink Faucet	7/29/16 9:41	8/5/16 13:08	608012821	LEAD	5 PPB	15 PPB
054-22A Classroom A6 Drinking Fountain	7/29/16 9:41	8/5/16 13:08	608012822	LEAD	1 PPB	15 PPB
054-23A Girls Bathroom Drinking Fountain	7/29/16 9:44	8/5/16 13:08	608012823	LEAD	< 1 PPB	15 PPB
054-24A Nurse Office Sink Faucet	7/29/16 9:47	8/5/16 13:08	608012824	LEAD	3 PPB	15 PPB
054-26A LRC Sink Faucet	7/29/16 9:56	8/5/16 13:08	608012825	LEAD	3 PPB	15 PPB
054-27A Hallway Drinking Fountain 3	7/29/16 10:00	8/5/16 13:08	608012826	LEAD	4 PPB	15 PPB
054-28A Classroom B1 Sink Faucet	7/29/16 10:03	8/5/16 13:08	608012827	LEAD	10 PPB	15 PPB
054-29A Classroom B1 Drinking Fountain	7/29/16 10:04	8/5/16 13:08	608012828	LEAD	2 PPB	15 PPB
054-30A Classroom B2 Sink Faucet	7/29/16 10:10	8/5/16 13:08	608012829	LEAD	8 PPB	15 PPB
054-31A Classroom B2 Drinking Fountain	7/29/16 10:10	8/5/16 13:08	608012830	LEAD	< 1 PPB	15 PPB
054-32A Classroom B3 Sink Faucet	7/29/16 10:14	8/5/16 13:08	608012831	LEAD	6 PPB	15 PPB
054-33A Classroom B3 Drinking Fountain	7/29/16 10:14	8/5/16 13:08	608012832	LEAD	< 1 PPB	15 PPB
054-34A Classroom B4 Sink Faucet	7/29/16 10:17	8/5/16 13:08	608012833	LEAD	17 PPB	15 PPB
054-35A Classroom B4 Drinking Fountain	7/29/16 10:17	8/5/16 13:08	608012834	LEAD	2 PPB	15 PPB
054-36A Classroom B5 Sink Faucet	7/29/16 10:21	8/5/16 13:08	608012835	LEAD	5 PPB	15 PPB
054-37A Classroom B5 Drinking Fountain	7/29/16 10:21	8/5/16 13:08	608012836	LEAD	2 PPB	15 PPB
054-38A Classroom B6 Sink Faucet	7/29/16 10:25	8/5/16 13:08	608012837	LEAD	6 PPB	15 PPB
054-39A Classroom B6 Drinking Fountain	7/29/16 10:25	8/5/16 13:08	608012838	LEAD	42 PPB	15 PPB
054-40A Hallway Drinking Fountain 4	7/29/16 10:28	8/5/16 13:08	608012839	LEAD	< 1 PPB	15 PPB
054-41A Classroom C1 Sink Faucet	7/29/16 10:31	8/5/16 13:08	608012840	LEAD	6 PPB	15 PPB
054-42A Classroom C1 Drinking Fountain	7/29/16 10:31	8/5/16 13:08	608012841	LEAD	< 1 PPB	15 PPB
054-43A Classroom C2 Sink Faucet	7/29/16 10:34	8/5/16 13:08	608012842	LEAD	< 1 PPB	15 PPB
054-44A Classroom C2 Drinking Fountain	7/29/16 10:34	8/5/16 13:08	608012843	LEAD	2 PPB	15 PPB
054-45A Classroom C3 Sink Faucet	7/29/16 10:39	8/5/16 13:09	608012844	LEAD	9 PPB	15 PPB
054-46A Classroom C3 Drinking Fountain	7/29/16 10:39	8/5/16 13:09	608012845	LEAD	1 PPB	15 PPB
054-47A Classroom C4 Sink Faucet	7/29/16 10:42	8/5/16 13:09	608012846	LEAD	8 PPB	15 PPB
054-48A Classroom C4 Drinking Fountain	7/29/16 10:42	8/5/16 13:09	608012847	LEAD	2 PPB	15 PPB
054-49A Classroom C5 Sink Faucet	7/29/16 10:45	8/5/16 13:09	608012848	LEAD	2 PPB	15 PPB
054-50A Classroom C5 Drinking Fountain	7/29/16 10:45	8/5/16 13:09	608012849	LEAD	< 1 PPB	15 PPB

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Sumpter Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
054-51A Classroom C6 Sink Faucet	7/29/16 10:50	8/5/16 13:09	608012850	LEAD	11 PPB	15 PPB
054-52A Classroom C6 Drinking Fountain	7/29/16 10:50	8/5/16 13:09	608012851	LEAD	1 PPB	15 PPB
054-53A Portable M1 Sink Faucet	7/29/16 10:59	8/5/16 13:09	608012852	LEAD	3 PPB	15 PPB
054-54A Portable M1 Drinking Fountain	7/29/16 10:59	8/5/16 13:09	608012853	LEAD	< 1 PPB	15 PPB
054-55A Portable M2 Sink Faucet	7/29/16 11:03	8/5/16 13:09	608012854	LEAD	3 PPB	15 PPB
054-56A Portable M2 Drinking Fountain	7/29/16 11:03	8/5/16 13:09	608012855	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Sumpter Elementary School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
054-03B Store Room Sink Faucet	7/29/16 9:00	8/24/16 12:48	608174001	LEAD	< 1 PPB	15 PPB
054-04B Music Room Sink Faucet	7/29/16 9:03	8/24/16 12:48	608174002	LEAD	2 PPB	15 PPB
054-34B Classroom B4 Sink Faucet	7/29/16 10:18	8/24/16 12:48	608174003	LEAD	3 PPB	15 PPB
054-39B Classroom B6 Drinking Fountain	7/29/16 10:26	8/25/16 14:40	608174004	LEAD	< 1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level