

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Transportation Department Building

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
67-01A Parts Room Drinking Fountain	7/23/2016 10:05	7/28/2016	43576	COPPER	0.3 PPM	1.3 PPM
67-02A North Shop Sink Faucet	7/23/2016 10:07	7/28/2016	43577	COPPER	0.0 PPM	1.3 PPM
67-03A North Shop Drinking Fountain	7/23/2016 10:09	7/28/2016	43578	COPPER	0.1 PPM	1.3 PPM
67-04A South Shop Sink Faucet	7/23/2016 10:11	7/28/2016	43579	COPPER	0.3 PPM	1.3 PPM
67-05A 1st Floor Break Room Sink Faucet	7/23/2016 10:13	7/28/2016	43580	COPPER	0.3 PPM	1.3 PPM
67-06A 2nd Floor Hall Drinking Fountain	7/23/2016 10:15	7/28/2016	43581	COPPER	0.3 PPM	1.3 PPM
67-07A 2nd Floor Break Room Sink Faucet	7/23/2016 10:17	7/28/2016	43582	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level