

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Triangle Square Program

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
80-01A Restroom Sink Faucet	8/5/2016 11:49	8/23/2016	49984	LEAD	5 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level