

Salem-Keizer Public Schools
Lead Water Sampling Results
First Draw (A) Sample Data
Valley Inquiry School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
056-01A Classroom 5 Sink Faucet	8/4/2016 10:38	8/23/2016	49892	LEAD	9 PPB	15 PPB
056-02A Classroom 5 Drinking Fountain	8/4/2016 10:38	8/23/2016	49893	LEAD	<1 PPB	15 PPB
056-03A Classroom 4 Sink Faucet	8/4/2016 10:40	8/23/2016	49894	LEAD	7 PPB	15 PPB
056-04A Classroom 4 Drinking Fountain	8/4/2016 10:40	8/23/2016	49895	LEAD	10 PPB	15 PPB
056-05A Room 6 Sink Faucet	8/4/2016 10:42	8/23/2016	49896	LEAD	3 PPB	15 PPB
056-06A Room 6 Drinking Fountain	8/4/2016 10:42	8/23/2016	49897	LEAD	<1 PPB	15 PPB
056-07A Classroom 3 Sink Faucet	8/4/2016 10:44	8/23/2016	49898	LEAD	11 PPB	15 PPB
056-08A Classroom 3 Drinking Fountain	8/4/2016 10:44	8/23/2016	49899	LEAD	9 PPB	15 PPB
056-09A Room 7 Sink Faucet	8/4/2016 10:46	8/23/2016	49900	LEAD	3 PPB	15 PPB
056-10A Room 7 Drinking Fountain	8/4/2016 10:46	8/23/2016	49901	LEAD	2 PPB	15 PPB
056-11A Room 2 Sink Faucet	8/4/2016 10:48	8/23/2016	49902	LEAD	11 PPB	15 PPB
056-12A Room 2 Drinking Fountain	8/4/2016 10:48	8/23/2016	49903	LEAD	1 PPB	15 PPB
056-13A Classroom 1 Sink Faucet	8/4/2016 10:50	8/23/2016	49904	LEAD	1 PPB	15 PPB
056-14A Classroom 1 Drinking Fountain	8/4/2016 10:50	8/23/2016	49905	LEAD	7 PPB	15 PPB
056-15A Hallway Drinking Fountain 1	8/4/2016 10:52	8/23/2016	49906	LEAD	11 PPB	15 PPB
056-16A Health Room Sink Faucet	8/4/2016 10:54	8/23/2016	49907	LEAD	6 PPB	15 PPB
056-17A Faculty Lounge Sink Faucet	8/4/2016 10:56	8/23/2016	49908	LEAD	<1 PPB	15 PPB
056-18A Kitchen Food Prep Sink Faucet	8/4/2016 10:59	8/23/2016	49909	LEAD	16 PPB	15 PPB
056-19A Kitchen Food Prep Sink Faucet	8/4/2016 11:01	8/23/2016	49910	LEAD	1 PPB	15 PPB
056-20A Kitchen Food Prep Sink Faucet	8/4/2016 11:03	8/23/2016	49911	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Lead Water Sampling Results
Flushed (B) Sample Data
Valley Inquiry School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
056-18B Kitchen Food Prep Sink Faucet	8/4/2016 11:00	9/1/2016	52476	LEAD	<1 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level