

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
Waldo Middle School

Sample Identification # and Location	Date/Time Sampled	Date/Time Analyzed	Container ID	Tested For	Results	Action Level
57-01A Boys Locker Room Drinking Fountain	8/5/16 5:59	8/15/16 9:28	608083801	COPPER	0.5 PPM	1.3 PPM
57-02A Hall Outside Boys Locker Room Drinking Fountain 1	8/5/16 6:03	8/15/16 9:28	608083802	COPPER	0.4 PPM	1.3 PPM
57-03A Gymnasium Drinking Fountain	8/5/16 6:07	8/15/16 9:28	608083803	COPPER	0.6 PPM	1.3 PPM
57-04A Storage Room (301/302) Sink Faucet	8/5/16 6:09	8/15/16 9:28	608083804	COPPER	0.3 PPM	1.3 PPM
57-05A Storage Room between 303 & 305 Sink Faucet	8/5/16 6:16	8/15/16 9:28	608083805	COPPER	0.4 PPM	1.3 PPM
57-06A Hallway Drinking Fountain 2	8/5/16 6:18	8/15/16 9:28	608083806	COPPER	0.4 PPM	1.3 PPM
57-07A Classroom 305 Sink Faucet	8/5/16 6:21	8/15/16 9:28	608083807	COPPER	0.4 PPM	1.3 PPM
57-08A Classroom 305 Sink Faucet	8/5/16 6:21	8/15/16 9:29	608083808	COPPER	0.4 PPM	1.3 PPM
57-09A Classroom 308 Sink Faucet	8/5/16 6:26	8/15/16 9:29	608083809	COPPER	0.4 PPM	1.3 PPM
57-10A Classroom 308 Drinking Fountain	8/5/16 6:26	8/15/16 9:30	608083810	COPPER	0.7 PPM	1.3 PPM
57-11A Classroom 307 Sink Faucet	8/5/16 6:28	8/15/16 9:30	608083811	COPPER	0.7 PPM	1.3 PPM
57-12A Classroom 310 Sink Faucet	8/5/16 6:30	8/18/16 11:01	608083812	COPPER	1.1 PPM	1.3 PPM
57-13A Classroom 310 Drinking Fountain	8/5/16 6:30	8/15/16 9:31	608083813	COPPER	0.6 PPM	1.3 PPM
57-14A Hall between CR 307, 309 Drinking Fountain 3	8/5/16 6:34	8/15/16 9:31	608083814	COPPER	1.0 PPM	1.3 PPM
57-15A Classroom 311 Home Economics Sink Faucet 1	8/5/16 6:42	8/15/16 9:31	608083815	COPPER	0.5 PPM	1.3 PPM
57-16A Classroom 311 Home Economics Sink Faucet 2	8/5/16 6:42	8/15/16 9:31	608083816	COPPER	0.3 PPM	1.3 PPM
57-17A Classroom 311 Home Economics Sink Faucet 3	8/5/16 6:43	8/15/16 9:31	608083817	COPPER	0.5 PPM	1.3 PPM
57-18A Classroom 311 Home Economics Sink Faucet 4	8/5/16 6:43	8/15/16 9:31	608083818	COPPER	0.4 PPM	1.3 PPM
57-19A Classroom 311 Home Economics Sink Faucet 5	8/5/16 6:43	8/15/16 9:31	608083819	COPPER	0.2 PPM	1.3 PPM
57-20A Classroom 311 Home Economics Sink Faucet 6	8/5/16 6:44	8/15/16 9:32	608083820	COPPER	0.2 PPM	1.3 PPM
57-21A Classroom 311 Home Economics Sink Faucet 7	8/5/16 6:44	8/15/16 9:32	608083821	COPPER	0.2 PPM	1.3 PPM
57-22A Girls Locker Room Drinking Fountain	8/5/16 7:01	8/15/16 9:32	608083822	COPPER	0.5 PPM	1.3 PPM
57-23A Hall across from Classroom 202 Drinking Fountain 4	8/5/16 6:54	8/15/16 9:32	608083823	COPPER	0.5 PPM	1.3 PPM
57-24A Hall by Room 214 Drinking Fountain 5	8/5/16 6:57	8/15/16 9:32	608083824	COPPER	0.6 PPM	1.3 PPM
57-25A Classroom by 216 Drinking Fountain 1	8/5/16 7:01	8/15/16 9:32	608083825	COPPER	0.6 PPM	1.3 PPM
57-26A Classroom by 216 Drinking Fountain 2	8/5/16 7:02	8/15/16 9:32	608083826	COPPER	0.6 PPM	1.3 PPM
57-27A Hallway across from 112 Water Fountain 6	8/5/16 5:59	8/15/16 9:32	608083827	COPPER	0.7 PPM	1.3 PPM
57-28A Classroom 112 Sink Faucet near Door	8/5/16 7:10	8/15/16 9:32	608083828	COPPER	0.5 PPM	1.3 PPM
57-29A Classroom 112 Sink Drinking Fountain	8/5/16 7:10	8/15/16 9:32	608083829	COPPER	0.5 PPM	1.3 PPM
57-30A AV Room Sink Faucet	8/5/16 7:14	8/15/16 9:33	608083830	COPPER	0.4 PPM	1.3 PPM
57-31A Nurses Station Sink Faucet (Office)	8/5/16 7:19	8/15/16 9:33	608083831	COPPER	0.1 PPM	1.3 PPM
57-32A Faculty Lounge Sink Faucet	8/5/16 7:23	8/15/16 9:33	608083832	COPPER	0.2 PPM	1.3 PPM
57-33A Classroom 104 Sink Faucet	8/5/16 7:30	8/15/16 9:33	608083833	COPPER	0.5 PPM	1.3 PPM
57-34A Classroom 102 Sink Faucet	8/5/16 7:51	8/15/16 9:33	608083834	COPPER	0.4 PPM	1.3 PPM
57-35A Hall Refrigerated Drinking Fountain 7	8/5/16 7:35	8/15/16 9:33	608083835	COPPER	0.1 PPM	1.3 PPM
57-36A Automated Water Bottle Refill	8/5/16 7:36	8/15/16 9:33	608083836	COPPER	0.2 PPM	1.3 PPM
57-37A Kitchen Sink Faucet (Eye Wash)	8/5/16 7:46	8/15/16 9:33	608083837	COPPER	0.3 PPM	1.3 PPM
57-38A Triple Sink Left Faucet	8/5/16 7:47	8/15/16 9:33	608083838	COPPER	0.2 PPM	1.3 PPM
57-39A Triple Sink Right Faucet	8/5/16 7:47	8/15/16 9:33	608083839	COPPER	0.4 PPM	1.3 PPM
57-40A Ice Maker	8/5/16 7:48	8/15/16 9:35	608083840	COPPER	0.1 PPM	1.3 PPM
57-41A Kitchen Sink Faucet	8/5/16 7:50	8/15/16 9:35	608083841	COPPER	0.2 PPM	1.3 PPM
57-42A Kitchen Produce Sink Faucet	8/5/16 7:51	8/15/16 9:35	608083842	COPPER	0.3 PPM	1.3 PPM
57-43A Kitchen Sink Faucet	8/5/16 7:52	8/15/16 9:35	608083843	COPPER	0.3 PPM	1.3 PPM
57-44A Skullery Sink Faucet	8/5/16 7:53	8/15/16 9:35	608083844	COPPER	0.2 PPM	1.3 PPM
57-45A Drinking Fountain Corridor next to Girls Locker Room 8	8/5/16 7:57	8/15/16 9:35	608083845	COPPER	0.2 PPM	1.3 PPM
57-46A Drinking Fountain outside Gymnasium 9	8/5/16 8:03	8/15/16 9:35	608083846	COPPER	0.0 PPM	1.3 PPM
57-47A Drinking Fountain outside Gymnasium 10	8/5/16 8:04	8/15/16 9:35	608083847	COPPER	0.0 PPM	1.3 PPM
57-48A Drinking Fountain in Music Room outside Gymnasium	8/5/16 8:10	8/15/16 9:35	608083848	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level