

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-01A Hallway Drinking Fountain #1	7/20/2016 7:55	7/27/2016	42760	COPPER	0.0 PPM	1.3 PPM
058-02A Room 108 Sink Faucet	7/20/2016 7:58	7/27/2016	42761	COPPER	0.0 PPM	1.3 PPM
058-03A Girls Locker Room Vestible Drinking Fountain	7/20/2016 8:07	7/27/2016	42762	COPPER	0.0 PPM	1.3 PPM
058-04A Girls Locker Room Drinking Fountain	7/20/2016 8:10	7/27/2016	42763	COPPER	0.1 PPM	1.3 PPM
058-05A Main Gymnasium Drinking Fountain-south	7/20/2016 8:12	7/27/2016	42764	COPPER	0.1 PPM	1.3 PPM
058-06A Main Gymnasium Drinking Fountain-north	7/20/2016 8:15	7/27/2016	42765	COPPER	0.0 PPM	1.3 PPM
058-07A Boy's Locker Room Vestibule Drinking Fountain	7/20/2016 8:17	7/27/2016	42766	COPPER	0.0 PPM	1.3 PPM
058-08A Boy's Locker Room Drinking Fountain	7/20/2016 8:19	7/27/2016	42767	COPPER	0.0 PPM	1.3 PPM
058-09A Gymnasium Hallway Drinking Fountian	7/20/2016 8:24	7/27/2016	42768	COPPER	0.2 PPM	1.3 PPM
058-10A Room 100 Sink Faucet	7/20/2016 8:26	7/27/2016	42769	COPPER	0.0 PPM	1.3 PPM
058-11A Room 105 Sink Faucet	7/20/2016 8:29	7/27/2016	42770	COPPER	0.0 PPM	1.3 PPM
058-12A Cafeteria Dinking Fountain(107)	7/20/2016 8:32	7/27/2016	42771	COPPER	0.4 PPM	1.3 PPM
058-13A Kitchen Sink Faucet East Wall (left)	7/20/2016 8:34	7/27/2016	42772	COPPER	0.1 PPM	1.3 PPM
058-14A Kitchen Sink Faucet East Wall (right)	7/20/2016 8:36	7/27/2016	42773	COPPER	0.2 PPM	1.3 PPM
058-15A Kitchen Sink Faucet- Westside Center	7/20/2016 8:39	7/27/2016	42774	COPPER	0.1 PPM	1.3 PPM
058-16A Kitchen Sink Faucet Wash Area	7/20/2016 8:41	7/27/2016	42775	COPPER	0.1 PPM	1.3 PPM
058-17A Kitchen Ice Machine	7/20/2016 8:44	7/27/2016	42776	COPPER	0.0 PPM	1.3 PPM
058-18A Cafeteria Drinking Fountain (109)	7/20/2016 8:47	7/27/2016	42777	COPPER	0.4 PPM	1.3 PPM
058-19A Main Office Sink Faucet	7/20/2016 8:49	7/27/2016	42778	COPPER	0.0 PPM	1.3 PPM
058-20A Main Hallway Drinking Fountain #2	7/20/2016 8:51	7/27/2016	42779	COPPER	0.5 PPM	1.3 PPM
058-21A Health Room Sink Faucet	7/20/2016 8:54	7/27/2016	42780	COPPER	0.0 PPM	1.3 PPM
058-22A Room 113 Sink Faucet	7/20/2016 8:56	7/27/2016	42781	COPPER	0.0 PPM	1.3 PPM
058-23A Room 115 Sink Faucet	7/20/2016 8:58	7/27/2016	42782	COPPER	0.0 PPM	1.3 PPM
058-24A Room 116 Sink Faucet	7/20/2016 9:00	7/27/2016	42783	COPPER	0.0 PPM	1.3 PPM
058-25A Room 130 Sink Faucet	7/20/2016 9:03	7/27/2016	42784	COPPER	0.2 PPM	1.3 PPM
058-26A Room 130 Drinking Fountain	7/20/2016 9:05	7/27/2016	42785	COPPER	0.2 PPM	1.3 PPM
058-27A Room 132 Sink Faucet	7/20/2016 9:09	7/27/2016	42786	COPPER	0.3 PPM	1.3 PPM
058-28A Room 132 Drinking Fountian	7/20/2016 9:11	7/27/2016	42787	COPPER	0.4 PPM	1.3 PPM
058-29A Room 131 Sink Faucet	7/20/2016 9:13	7/27/2016	42788	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-30A Room 131 Drinking Fountain	7/20/2016 9:15	7/27/2016	42789	COPPER	0.2 PPM	1.3 PPM
058-31A Room 133 Sink Faucet	7/20/2016 9:17	7/27/2016	42790	COPPER	0.2 PPM	1.3 PPM
058-32A Room 133 Sink Fountain	7/20/2016 9:19	7/27/2016	42791	COPPER	0.2 PPM	1.3 PPM
058-33A Room 134 Sink Faucet	7/20/2016 9:21	7/27/2016	42792	COPPER	0.3 PPM	1.3 PPM
058-34A Room 134 Drinking Fountain	7/20/2016 9:23	7/27/2016	42793	COPPER	0.2 PPM	1.3 PPM
058-35A Room 135 Sink Faucet	7/20/2016 9:25	7/27/2016	42794	COPPER	0.3 PPM	1.3 PPM
058-36A Room 135 Drinking Fountain	7/20/2016 9:27	7/27/2016	42795	COPPER	0.3 PPM	1.3 PPM
058-37A Library Room 137 Sink Faucet	7/20/2016 9:29	7/27/2016	42796	COPPER	0.3 PPM	1.3 PPM
058-38A Library Room 137 Drinking Fountain	7/20/2016 9:31	7/27/2016	42797	COPPER	0.4 PPM	1.3 PPM
058-39A Hallway Drinking Fountain #3	7/20/2016 9:35	7/27/2016	42798	COPPER	0.2 PPM	1.3 PPM
058-40A Music Storage Area Sink Faucet	7/20/2016 9:39	7/27/2016	42799	COPPER	0.2 PPM	1.3 PPM
058-41A Music Storage Area Drinking Fountain	7/20/2016 9:41	7/27/2016	42800	COPPER	0.1 PPM	1.3 PPM
058-42A Band Room 125 Sink Faucet	7/20/2016 9:43	7/27/2016	42801	COPPER	0.3 PPM	1.3 PPM
058-43A Band Room 125 Drinking Fountain	7/20/2016 9:45	7/27/2016	42802	COPPER	0.3 PPM	1.3 PPM
058-44A Room 226 Sink Faucet	7/20/2016 9:49	7/27/2016	42803	COPPER	0.0 PPM	1.3 PPM
058-45A 2nd Floor Hall Drinking Fountain #4	7/20/2016 9:52	7/27/2016	42804	COPPER	0.3 PPM	1.3 PPM
058-46A Room 222 Sink Faucet (Left)	7/20/2016 9:55	7/27/2016	42805	COPPER	0.1 PPM	1.3 PPM
058-47A Room 222 Sink Faucet (Right)	7/20/2016 9:57	7/27/2016	42806	COPPER	0.0 PPM	1.3 PPM
058-48A Room 222 Sink Faucet (West)	7/20/2016 9:59	7/27/2016	42807	COPPER	0.0 PPM	1.3 PPM
058-49A Room 231 Sink Faucet	7/20/2016 10:05	7/27/2016	42808	COPPER	0.3 PPM	1.3 PPM
058-50A Room 231 Drinking Fountain	7/20/2016 10:07	7/27/2016	42809	COPPER	0.3 PPM	1.3 PPM
058-51A Room 230 Sink Faucet	7/20/2016 10:09	7/27/2016	42810	COPPER	0.3 PPM	1.3 PPM
058-52A Room 230 Drinking Fountain	7/20/2016 10:11	7/27/2016	42811	COPPER	0.3 PPM	1.3 PPM
058-53A Room 232 Sink Faucet	7/20/2016 10:13	7/27/2016	42812	COPPER	0.5 PPM	1.3 PPM
058-54A Room 232 Drinking Fountain	7/20/2016 10:15	7/27/2016	42813	COPPER	0.2 PPM	1.3 PPM
058-55A Room 233 Sink Faucet	7/20/2016 10:17	7/27/2016	42814	COPPER	0.3 PPM	1.3 PPM
058-56A Room 233 Drinking Fountain	7/20/2016 10:19	7/27/2016	42815	COPPER	0.2 PPM	1.3 PPM
058-57A Room 234 Sink Faucet	7/20/2016 10:21	7/27/2016	42816	COPPER	0.4 PPM	1.3 PPM
058-58A Room 234 Drinking Fountain	7/20/2016 10:23	7/27/2016	42817	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-59A Room 236 Sink Faucet	7/20/2016 10:25	7/27/2016	42818	COPPER	0.5 PPM	1.3 PPM
058-60A Room 236 Drinking Fountain	7/20/2016 10:27	7/27/2016	42819	COPPER	0.5 PPM	1.3 PPM
058-61A Room 235 Sink Faucet	7/20/2016 10:29	7/27/2016	42820	COPPER	0.3 PPM	1.3 PPM
058-62A Room 235 Drinking Fountain	7/20/2016 10:31	7/27/2016	42821	COPPER	0.3 PPM	1.3 PPM
058-63A Room 237 Sink Faucet	7/20/2016 10:33	7/27/2016	42822	COPPER	0.4 PPM	1.3 PPM
058-64A Room 237 Drinking Fountain	7/20/2016 10:35	7/27/2016	42823	COPPER	0.4 PPM	1.3 PPM
058-65A Room 238 Sink Faucet	7/20/2016 10:37	7/27/2016	42824	COPPER	0.4 PPM	1.3 PPM
058-66A Room 238 Drinking Fountain	7/20/2016 10:39	7/27/2016	42825	COPPER	0.5 PPM	1.3 PPM
058-67A Room 240 Sink Faucet	7/20/2016 10:42	7/27/2016	42826	COPPER	0.6 PPM	1.3 PPM
058-68A Room 240 Drinking Fountain	7/20/2016 10:44	7/27/2016	42827	COPPER	0.5 PPM	1.3 PPM
058-69A Room 239 Sink Faucet	7/20/2016 10:46	7/27/2016	42828	COPPER	0.4 PPM	1.3 PPM
058-70A Room 239 Drinking Fountain	7/20/2016 10:48	7/27/2016	42829	COPPER	0.3 PPM	1.3 PPM
058-71A Room 241 Sink Faucet	7/20/2016 10:50	7/27/2016	42830	COPPER	1.0 PPM	1.3 PPM
058-72A Room 241 Drinking Fountain	7/20/2016 10:52	7/27/2016	42831	COPPER	0.5 PPM	1.3 PPM
058-73A Room 218 Sink Faucet	7/20/2016 10:55	7/27/2016	42832	COPPER	0.4 PPM	1.3 PPM
058-74A Room 217 Sink Faucet	7/20/2016 10:57	7/27/2016	42833	COPPER	0.0 PPM	1.3 PPM
058-75A Room 217 Drinking Fountain	7/20/2016 10:59	7/27/2016	42834	COPPER	0.0 PPM	1.3 PPM
058-76A Room 215 Sink Faucet (Left)	7/20/2016 11:01	7/27/2016	42835	COPPER	0.3 PPM	1.3 PPM
058-77A Room 215 Sink Faucet (Right)	7/20/2016 11:03	7/27/2016	42836	COPPER	0.2 PPM	1.3 PPM
058-78A Room 215 Drinking Fountain	7/20/2016 11:05	7/27/2016	42837	COPPER	0.0 PPM	1.3 PPM
058-79A Room 213 Sink Faucet (Front/Center)	7/20/2016 11:10	7/27/2016	42838	COPPER	0.0 PPM	1.3 PPM
058-80A Room 213 Sink Faucet (South Wall Left)	7/20/2016 11:12	7/27/2016	42839	COPPER	0.0 PPM	1.3 PPM
058-81A Room 213 Sink Faucet (South Wall Center)	7/20/2016 11:14	7/27/2016	42840	COPPER	0.0 PPM	1.3 PPM
058-82A Room 213 Sink Faucet (South Wall Right)	7/20/2016 11:16	7/27/2016	42841	COPPER	0.0 PPM	1.3 PPM
058-83A Room 213 Sink Faucet (North Wall Left)	7/20/2016 11:18	7/27/2016	42842	COPPER	0.0 PPM	1.3 PPM
058-84A Room 213 Sink Faucet (North Wall Center)	7/20/2016 11:20	7/27/2016	42843	COPPER	0.0 PPM	1.3 PPM
058-85A Room 213 Sink Faucet (North Wall Right)	7/20/2016 11:22	7/27/2016	42844	COPPER	0.0 PPM	1.3 PPM
058-86A 2nd Floor Hallway Drinking Fountain #5	7/20/2016 11:25	7/27/2016	42845	COPPER	0.0 PPM	1.3 PPM
058-87A Auxillary Gymnasium Drinking Fountain	7/20/2016 11:33	7/27/2016	42846	COPPER	0.2 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-88A Auxillary Gymnasium Drinking Fountain	7/20/2016 11:36	7/27/2016	42847	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (C) Sample Data  
 Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-04C Girls Locker Room Drinking Fountain	1/6/2017 5:10	1/9/2017	768	COPPER	0.0 PPM	1.3 PPM
058-05C Main Gymnasium Drinking Fountain - South	1/6/2017 5:13	1/9/2017	769	COPPER	0.0 PPM	1.3 PPM
058-06C Main Gymnasium Drinking Fountain - North	1/6/2017 5:16	1/9/2017	770	COPPER	0.0 PPM	1.3 PPM
058-08C Boys locker Room Drinking Fountain	1/6/2017 5:19	1/9/2017	771	COPPER	0.0 PPM	1.3 PPM
058-11C Room 105 Sink Faucet	1/6/2017 5:22	1/9/2017	772	COPPER	0.1 PPM	1.3 PPM
058-39C Hallway Drinking Fountain #3	1/6/2017 4:45	1/9/2017	773	COPPER	0.2 PPM	1.3 PPM
058-76C Room 215 Sink Faucet (Left)	1/6/2017 5:04	1/9/2017	774	COPPER	0.2 PPM	1.3 PPM
058-85C Room 213 Sink Faucet (North Wall Right)	1/6/2017 5:01	1/9/2017	775	COPPER	0.1 PPM	1.3 PPM
058-86C 2nd Floor Hallway Drinking Fountain #5	1/6/2017 5:01	1/9/2017	776	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 Flushed (D) Sample Data  
 Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-04D Girls Locker Room Drinking Fountain	1/6/2017 5:11	2/1/2017	4394	COPPER	0.0 PPM	1.3 PPM
058-06D Main Gymnasium Drinking Fountain - North	1/6/2017 5:17	2/1/2017	4395	COPPER	0.0 PPM	1.3 PPM
058-08D Boys locker Room Drinking Fountain	1/6/2017 5:20	2/1/2017	4396	COPPER	<0.005 PPM	1.3 PPM
058-86D 2nd Floor Hallway Drinking Fountain #5	1/6/2017 5:02	2/1/2017	4397	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (E) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-04E Girls Locker Room Drinking Fountain	4/6/2017 5:39	4/11/2017	18109	COPPER	0.0 PPM	1.3 PPM
058-06E Main Gymnasium Drinking Fountain: North	4/5/2017 5:44	4/11/2017	18110	COPPER	0.1 PPM	1.3 PPM
058-08E Boys Locker Room Drinking Fountain	4/5/2017 5:47	4/11/2017	18111	COPPER	0.0 PPM	1.3 PPM
058-86E 2nd Floor Hallway Drinking Fountain #5	4/5/2017 5:53	4/11/2017	18112	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**