

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-01A Hallway Drinking Fountain #1	7/20/2016 7:55	7/27/2016	42760	LEAD	4 PPB	15 PPB
058-02A Room 108 Sink Faucet	7/20/2016 7:58	7/27/2016	42761	LEAD	6 PPB	15 PPB
058-03A Girls Locker Room Vestible Drinking Fountain	7/20/2016 8:07	7/27/2016	42762	LEAD	7 PPB	15 PPB
058-04A Girls Locker Room Drinking Fountain	7/20/2016 8:10	7/27/2016	42763	LEAD	69 PPB	15 PPB
058-05A Main Gymnasium Drinking Fountain-south	7/20/2016 8:12	7/27/2016	42764	LEAD	19 PPB	15 PPB
058-06A Main Gymnasium Drinking Fountain-north	7/20/2016 8:15	7/27/2016	42765	LEAD	43 PPB	15 PPB
058-07A Boy's Locker Room Vestibule Drinking Fountain	7/20/2016 8:17	7/27/2016	42766	LEAD	8 PPB	15 PPB
058-08A Boy's Locker Room Drinking Fountain	7/20/2016 8:19	7/27/2016	42767	LEAD	67 PPB	15 PPB
058-09A Gymnasium Hallway Drinking Fountain	7/20/2016 8:24	7/27/2016	42768	LEAD	13 PPB	15 PPB
058-10A Room 100 Sink Faucet	7/20/2016 8:26	7/27/2016	42769	LEAD	3 PPB	15 PPB
058-11A Room 105 Sink Faucet	7/20/2016 8:29	7/27/2016	42770	LEAD	17 PPB	15 PPB
058-12A Cafeteria Dinking Fountain(107)	7/20/2016 8:32	7/27/2016	42771	LEAD	3 PPB	15 PPB
058-13A Kitchen Sink Faucet East Wall (left)	7/20/2016 8:34	7/27/2016	42772	LEAD	2 PPB	15 PPB
058-14A Kitchen Sink Faucet East Wall (right)	7/20/2016 8:36	7/27/2016	42773	LEAD	2 PPB	15 PPB
058-15A Kitchen Sink Faucet- Westside Center	7/20/2016 8:39	7/27/2016	42774	LEAD	1 PPB	15 PPB
058-16A Kitchen Sink Faucet Wash Area	7/20/2016 8:41	7/27/2016	42775	LEAD	<1 PPB	15 PPB
058-17A Kitchen Ice Machine	7/20/2016 8:44	7/27/2016	42776	LEAD	<1 PPB	15 PPB
058-18A Cafeteria Drinking Fountain (109)	7/20/2016 8:47	7/27/2016	42777	LEAD	2 PPB	15 PPB
058-19A Main Office Sink Faucet	7/20/2016 8:49	7/27/2016	42778	LEAD	4 PPB	15 PPB
058-20A Main Hallway Drinking Fountain #2	7/20/2016 8:51	7/27/2016	42779	LEAD	4 PPB	15 PPB
058-21A Health Room Sink Faucet	7/20/2016 8:54	7/27/2016	42780	LEAD	5 PPB	15 PPB
058-22A Room 113 Sink Faucet	7/20/2016 8:56	7/27/2016	42781	LEAD	4 PPB	15 PPB
058-23A Room 115 Sink Faucet	7/20/2016 8:58	7/27/2016	42782	LEAD	4 PPB	15 PPB
058-24A Room 116 Sink Faucet	7/20/2016 9:00	7/27/2016	42783	LEAD	3 PPB	15 PPB
058-25A Room 130 Sink Faucet	7/20/2016 9:03	7/27/2016	42784	LEAD	7 PPB	15 PPB
058-26A Room 130 Drinking Fountain	7/20/2016 9:05	7/27/2016	42785	LEAD	1 PPB	15 PPB
058-27A Room 132 Sink Faucet	7/20/2016 9:09	7/27/2016	42786	LEAD	2 PPB	15 PPB
058-28A Room 132 Drinking Fountian	7/20/2016 9:11	7/27/2016	42787	LEAD	<1 PPB	15 PPB
058-29A Room 131 Sink Faucet	7/20/2016 9:13	7/27/2016	42788	LEAD	6 PPB	15 PPB
058-30A Room 131 Drinking Fountian	7/20/2016 9:15	7/27/2016	42789	LEAD	4 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-31A Room 133 Sink Faucet	7/20/2016 9:17	7/27/2016	42790	LEAD	5 PPB	15 PPB
058-32A Room 133 Dink Fountain	7/20/2016 9:19	7/27/2016	42791	LEAD	1 PPB	15 PPB
058-33A Room 134 Sink Faucet	7/20/2016 9:21	7/27/2016	42792	LEAD	2 PPB	15 PPB
058-34A Room 134 Drinking Fountain	7/20/2016 9:23	7/27/2016	42793	LEAD	<1 PPB	15 PPB
058-35A Room 135 Sink Faucet	7/20/2016 9:25	7/27/2016	42794	LEAD	4 PPB	15 PPB
058-36A Room 135 Drinking Fountain	7/20/2016 9:27	7/27/2016	42795	LEAD	2 PPB	15 PPB
058-37A Library Room 137 Sink Faucet	7/20/2016 9:29	7/27/2016	42796	LEAD	2 PPB	15 PPB
058-38A Library Room 137 Drinking Fountain	7/20/2016 9:31	7/27/2016	42797	LEAD	8 PPB	15 PPB
<b>058-39A Hallway Drinking Fountain #3</b>	<b>7/20/2016 9:35</b>	<b>7/27/2016</b>	<b>42798</b>	<b>LEAD</b>	<b>15 PPB</b>	<b>15 PPB</b>
058-40A Music Storage Area Sink Faucet	7/20/2016 9:39	7/27/2016	42799	LEAD	4 PPB	15 PPB
058-41A Music Storage Area Drinking Fountain	7/20/2016 9:41	7/27/2016	42800	LEAD	1 PPB	15 PPB
058-42A Band Room 125 Sink Faucet	7/20/2016 9:43	7/27/2016	42801	LEAD	5 PPB	15 PPB
058-43A Band Room 125 Drinking Fountain	7/20/2016 9:45	7/27/2016	42802	LEAD	<1 PPB	15 PPB
058-44A Room 226 Sink Faucet	7/20/2016 9:49	7/27/2016	42803	LEAD	3 PPB	15 PPB
058-45A 2nd Floor Hall Drinking Fountain #4	7/20/2016 9:52	7/27/2016	42804	LEAD	13 PPB	15 PPB
058-46A Room 222 Sink Faucet (Left)	7/20/2016 9:55	7/27/2016	42805	LEAD	6 PPB	15 PPB
058-47A Room 222 Sink Faucet (Right)	7/20/2016 9:57	7/27/2016	42806	LEAD	2 PPB	15 PPB
058-48A Room 222 Sink Faucet (West)	7/20/2016 9:59	7/27/2016	42807	LEAD	6 PPB	15 PPB
058-49A Room 231 Sink Faucet	7/20/2016 10:05	7/27/2016	42808	LEAD	4 PPB	15 PPB
058-50A Room 231 Drinking Fountain	7/20/2016 10:07	7/27/2016	42809	LEAD	6 PPB	15 PPB
058-51A Room 230 Sink Faucet	7/20/2016 10:09	7/27/2016	42810	LEAD	2 PPB	15 PPB
058-52A Room 230 Drinking Fountain	7/20/2016 10:11	7/27/2016	42811	LEAD	<1 PPB	15 PPB
058-53A Room 232 Sink Faucet	7/20/2016 10:13	7/27/2016	42812	LEAD	9 PPB	15 PPB
058-54A Room 232 Drinking Fountain	7/20/2016 10:15	7/27/2016	42813	LEAD	<1 PPB	15 PPB
058-55A Room 233 Sink Faucet	7/20/2016 10:17	7/27/2016	42814	LEAD	4 PPB	15 PPB
058-56A Room 233 Drinking Fountain	7/20/2016 10:19	7/27/2016	42815	LEAD	2 PPB	15 PPB
058-57A Room 234 Sink Faucet	7/20/2016 10:21	7/27/2016	42816	LEAD	4 PPB	15 PPB
058-58A Room 234 Drinking Fountain	7/20/2016 10:23	7/27/2016	42817	LEAD	<1 PPB	15 PPB
058-59A Room 236 Sink Faucet	7/20/2016 10:25	7/27/2016	42818	LEAD	4 PPB	15 PPB
058-60A Room 236 Drinking Fountain	7/20/2016 10:27	7/27/2016	42819	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-61A Room 235 Sink Faucet	7/20/2016 10:29	7/27/2016	42820	LEAD	5 PPB	15 PPB
058-62A Room 235 Drinking Fountain	7/20/2016 10:31	7/27/2016	42821	LEAD	<1 PPB	15 PPB
058-63A Room 237 Sink Faucet	7/20/2016 10:33	7/27/2016	42822	LEAD	5 PPB	15 PPB
058-64A Room 237 Drinking Fountain	7/20/2016 10:35	7/27/2016	42823	LEAD	<1 PPB	15 PPB
058-65A Room 238 Sink Faucet	7/20/2016 10:37	7/27/2016	42824	LEAD	5 PPB	15 PPB
058-66A Room 238 Drinking Fountain	7/20/2016 10:39	7/27/2016	42825	LEAD	<1 PPB	15 PPB
058-67A Room 240 Sink Faucet	7/20/2016 10:42	7/27/2016	42826	LEAD	6 PPB	15 PPB
058-68A Room 240 Drinking Fountain	7/20/2016 10:44	7/27/2016	42827	LEAD	<1 PPB	15 PPB
058-69A Room 239 Sink Faucet	7/20/2016 10:46	7/27/2016	42828	LEAD	7 PPB	15 PPB
058-70A Room 239 Drinking Fountain	7/20/2016 10:48	7/27/2016	42829	LEAD	<1 PPB	15 PPB
058-71A Room 241 Sink Faucet	7/20/2016 10:50	7/27/2016	42830	LEAD	5 PPB	15 PPB
058-72A Room 241 Drinking Fountain	7/20/2016 10:52	7/27/2016	42831	LEAD	3 PPB	15 PPB
058-73A Room 218 Sink Faucet	7/20/2016 10:55	7/27/2016	42832	LEAD	1 PPB	15 PPB
058-74A Room 217 Sink Faucet	7/20/2016 10:57	7/27/2016	42833	LEAD	4 PPB	15 PPB
058-75A Room 217 Drinking Fountain	7/20/2016 10:59	7/27/2016	42834	LEAD	3 PPB	15 PPB
<b>058-76A Room 215 Sink Faucet (Left)</b>	<b>7/20/2016 11:01</b>	<b>7/27/2016</b>	<b>42835</b>	<b>LEAD</b>	<b>15 PPB</b>	<b>15 PPB</b>
058-77A Room 215 Sink Faucet (Right)	7/20/2016 11:03	7/27/2016	42836	LEAD	9 PPB	15 PPB
058-78A Room 215 Drinking Fountain	7/20/2016 11:05	7/27/2016	42837	LEAD	3 PPB	15 PPB
058-79A Room 213 Sink Faucet (Front/Center)	7/20/2016 11:10	7/27/2016	42838	LEAD	6 PPB	15 PPB
058-80A Room 213 Sink Faucet (South Wall Left)	7/20/2016 11:12	7/27/2016	42839	LEAD	2 PPB	15 PPB
058-81A Room 213 Sink Faucet (South Wall Center)	7/20/2016 11:14	7/27/2016	42840	LEAD	2 PPB	15 PPB
058-82A Room 213 Sink Faucet (South Wall Right)	7/20/2016 11:16	7/27/2016	42841	LEAD	12 PPB	15 PPB
058-83A Room 213 Sink Faucet (North Wall Left)	7/20/2016 11:18	7/27/2016	42842	LEAD	6 PPB	15 PPB
058-84A Room 213 Sink Faucet (North Wall Center)	7/20/2016 11:20	7/27/2016	42843	LEAD	2 PPB	15 PPB
<b>058-85A Room 213 Sink Faucet (North Wall Right)</b>	<b>7/20/2016 11:22</b>	<b>7/27/2016</b>	<b>42844</b>	<b>LEAD</b>	<b>15 PPB</b>	<b>15 PPB</b>
<b>058-86A 2nd Floor Hallway Drinking Fountain #5</b>	<b>7/20/2016 11:25</b>	<b>7/27/2016</b>	<b>42845</b>	<b>LEAD</b>	<b>15 PPB</b>	<b>15 PPB</b>
058-87A Auxillary Gymnasium Drinking Fountain	7/20/2016 11:33	7/27/2016	42846	LEAD	2 PPB	15 PPB
058-88A Auxillary Gymnasium Drinking Fountain	7/20/2016 11:36	7/27/2016	42847	LEAD	2 PPB	15 PPB

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (A) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
--------------------------------------	-------------------	---------------	--------------	------------	---------	--------------

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
First Draw (C) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-04C Girls Locker Room Drinking Fountain	1/6/2017 5:10	1/9/2017	768	LEAD	16 PPB	15 PPB
058-05C Main Gymnasium Drinking Fountain - South	1/6/2017 5:13	1/9/2017	769	LEAD	3 PPB	15 PPB
058-06C Main Gymnasium Drinking Fountain - North	1/6/2017 5:16	1/9/2017	770	LEAD	44 PPB	15 PPB
058-08C Boys locker Room Drinking Fountain	1/6/2017 5:19	1/9/2017	771	LEAD	22 PPB	15 PPB
058-11C Room 105 Sink Faucet	1/6/2017 5:22	1/9/2017	772	LEAD	6 PPB	15 PPB
058-39C Hallway Drinking Fountain #3	1/6/2017 4:45	1/9/2017	773	LEAD	13 PPB	15 PPB
058-76C Room 215 Sink Faucet (Left)	1/6/2017 5:04	1/9/2017	774	LEAD	5 PPB	15 PPB
058-85C Room 213 Sink Faucet (North Wall Right)	1/6/2017 5:01	1/9/2017	775	LEAD	7 PPB	15 PPB
058-86C 2nd Floor Hallway Drinking Fountain #5	1/6/2017 5:01	1/9/2017	776	LEAD	20 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (B) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-04B Girls Locker Room Drinking Fountain	7/20/2016 8:11	9/6/2016	52974	LEAD	20 PPB	15 PPB
058-05B Main Gymnasium Drinking Fountain-south	7/20/2016 8:13	9/6/2016	52975	LEAD	6 PPB	15 PPB
058-06B Main Gymnasium Drinking Fountain-north	7/20/2016 8:16	9/6/2016	52976	LEAD	47 PPB	15 PPB
058-08B Boy's Locker Room Drinking Fountain	7/20/2016 8:18	9/19/2016	52977	LEAD	18 PPB	15 PPB
058-11B Room 105 Sink Faucet	7/20/2016 8:30	9/6/2016	52978	LEAD	8 PPB	15 PPB
058-39B Hallway Drinking Fountain #3	7/20/2016 9:36	9/6/2016	52979	LEAD	23 PPB	15 PPB
058-76B Room 215 Sink Faucet (Left)	7/20/2016 11:02	9/6/2016	52980	LEAD	3 PPB	15 PPB
058-85B Room 213 Sink Faucet (North Wall Right)	7/20/2016 11:23	9/6/2016	52981	LEAD	<1 PPB	15 PPB
058-86B 2nd Floor Hallway Drinking Fountain #5	7/20/2016 11:26	9/6/2016	52982	LEAD	11 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

**SKPS Action Level for Lead is 15 PPB**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Lead Water Sampling Results  
Flushed (D) Sample Data  
Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-04D Girls Locker Room Drinking Fountain	1/6/2017 5:11	2/1/2017	4394	LEAD	9 PPB	15 PPB
058-06D Main Gymnasium Drinking Fountain-north	1/6/2017 5:17	2/1/2017	4395	LEAD	55 PPB	15 PPB
058-08D Boy Locker Room Drinking Fountain	1/6/2017 5:20	2/1/2017	4396	LEAD	9 PPB	15 PPB
058-86D 2nd Floor Hallway Drinking Fountain #5	1/6/2017 5:02	2/1/2017	4397	LEAD	17 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools  
 Lead Water Sampling Results  
 First Draw (E) Sample Data  
 Walker Middle School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
058-04E Girls Locker Room Drinking Fountain	4/6/2017 5:39	4/11/2017	18109	LEAD	19 PPB	15 PPB
058-06E Main Gymnasium Drinking Fountain: North	4/5/2017 5:44	4/11/2017	18110	LEAD	96 PPB	15 PPB
058-08E Boys Locker Room Drinking Fountain	4/5/2017 5:47	4/11/2017	18111	LEAD	51 PPB	15 PPB
058-86E 2nd Floor Hallway Drinking Fountain #5	4/5/2017 5:53	4/11/2017	18112	LEAD	12 PPB	15 PPB

EPA Action Level for Lead in Schools is 20 PPB

SKPS Action Level for Lead is 15 PPB

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level