

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Washington Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
59-01A Cafeteria Drinking Fountain	7/22/2016 11:53	8/2/2016	44120	COPPER	0.5 PPM	1.3 PPM
59-02A Kitchen Sink Faucet (west wall)	7/22/2016 11:55	8/2/2016	44121	COPPER	0.6 PPM	1.3 PPM
59-03A Kitchen Sink Faucet (south wall)	7/22/2016 11:57	8/2/2016	44122	COPPER	0.3 PPM	1.3 PPM
59-04A Cafeteria Hall Drinking Fountain	7/22/2016 11:59	8/2/2016	44123	COPPER	0.4 PPM	1.3 PPM
59-05A Room 19 Sink Faucet	7/22/2016 12:01	8/2/2016	44124	COPPER	0.2 PPM	1.3 PPM
59-06A Room 19 Drinking Fountain	7/22/2016 12:03	8/2/2016	44125	COPPER	0.1 PPM	1.3 PPM
59-07A Room 18 Sink Faucet	7/22/2016 12:05	8/2/2016	44126	COPPER	0.2 PPM	1.3 PPM
59-08A Room 18 Drinking Fountain	7/22/2016 12:07	8/2/2016	44127	COPPER	0.2 PPM	1.3 PPM
59-09A Room 17 Sink Faucet	7/22/2016 12:09	8/2/2016	44128	COPPER	0.2 PPM	1.3 PPM
59-10A Room 17 Drinking Fountain	7/22/2016 12:10	8/2/2016	44129	COPPER	0.4 PPM	1.3 PPM
59-11A Room 1 Sink Faucet	7/22/2016 12:13	8/2/2016	44130	COPPER	0.1 PPM	1.3 PPM
59-12A Room 1 Drinkiing Fountain	7/22/2016 12:15	8/2/2016	44131	COPPER	0.2 PPM	1.3 PPM
59-13A Office Hallway Drinking Fountain (left)	7/22/2016 12:17	8/2/2016	44132	COPPER	0.3 PPM	1.3 PPM
59-14A Office Hallway Drinking Fountain (right)	7/22/2016 12:19	8/2/2016	44133	COPPER	0.4 PPM	1.3 PPM
59-15A Main Office Sink Faucet	7/22/2016 12:21	8/2/2016	44134	COPPER	0.2 PPM	1.3 PPM
59-16A Health Room Sink Faucet	7/22/2016 12:23	8/2/2016	44135	COPPER	0.5 PPM	1.3 PPM
59-17A Staff Room Sink Faucet	7/22/2016 12:25	8/2/2016	44136	COPPER	0.4 PPM	1.3 PPM
59-18A Room 2 Sink Faucet	7/22/2016 12:27	8/2/2016	44137	COPPER	0.1 PPM	1.3 PPM
59-19A Room 16 Sink Faucet	7/22/2016 12:29	8/2/2016	44138	COPPER	0.2 PPM	1.3 PPM
59-20A Room 16 Drinkinkg Fountain	7/22/2016 12:31	8/2/2016	44139	COPPER	0.2 PPM	1.3 PPM
59-21A Room 13 Sink Faucet	7/22/2016 12:33	8/2/2016	44140	COPPER	0.2 PPM	1.3 PPM
59-22A Room 13 Drinking Fountain	7/22/2016 12:35	8/2/2016	44141	COPPER	0.3 PPM	1.3 PPM
59-23A Room 15 Sink Faucet	7/22/2016 12:37	8/2/2016	44142	COPPER	0.1 PPM	1.3 PPM
59-24A Room 15 Drinking Fountain	7/22/2016 12:39	8/2/2016	44143	COPPER	0.1 PPM	1.3 PPM
59-25A Room 14 Sink Faucet	7/22/2016 12:41	8/2/2016	44144	COPPER	0.2 PPM	1.3 PPM
59-26A Room 14 Drinking Fountain	7/22/2016 12:43	8/2/2016	44145	COPPER	0.3 PPM	1.3 PPM
59-27A Library Sink Faucet	7/22/2016 12:45	8/2/2016	44146	COPPER	0.2 PPM	1.3 PPM
59-28A Room 12 Sink Faucet	7/22/2016 12:47	8/2/2016	44147	COPPER	0.2 PPM	1.3 PPM
59-29A Room 12 Drinking Fountain	7/22/2016 12:49	8/2/2016	44148	COPPER	0.3 PPM	1.3 PPM
59-30A Media Room Sink Faucet	7/22/2016 12:51	8/2/2016	44149	COPPER	0.3 PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Washington Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
59-31A Media Room Drinking Fountain	7/22/2016 12:53	8/2/2016	44150	COPPER	0.4 PPM	1.3 PPM
59-32A Room 11 Sink Faucet	7/22/2016 12:55	8/2/2016	44151	COPPER	0.2 PPM	1.3 PPM
59-33A Room 11 Drinking Fountain	7/22/2016 12:57	8/2/2016	44152	COPPER	0.2 PPM	1.3 PPM
59-34A Room 4 Sink Faucet	7/22/2016 12:59	8/2/2016	44153	COPPER	0.2 PPM	1.3 PPM
59-35A Room 4 Drinking Fountain	7/22/2016 13:01	8/2/2016	44154	COPPER	0.3 PPM	1.3 PPM
59-36A Room 10 Sink Faucet	7/22/2016 13:03	8/2/2016	44155	COPPER	0.3 PPM	1.3 PPM
59-37A Room 10 Drinking Fountain	7/22/2016 13:05	8/2/2016	44156	COPPER	0.3 PPM	1.3 PPM
59-38A Room 5 Sink Faucet	7/22/2016 13:07	8/2/2016	44157	COPPER	0.2 PPM	1.3 PPM
59-39A Room 5 Drinking Fountain	7/22/2016 13:09	8/2/2016	44158	COPPER	0.4 PPM	1.3 PPM
59-40A Room 6 Sink Faucet	7/22/2016 13:11	8/2/2016	44159	COPPER	0.2 PPM	1.3 PPM
59-41A Room 6 Drinking Fountain	7/22/2016 13:13	8/2/2016	44160	COPPER	0.3 PPM	1.3 PPM
59-42A Room 9 Sink Faucet	7/22/2016 13:15	8/2/2016	44161	COPPER	0.2 PPM	1.3 PPM
59-43A Room 9 Drinking Fountain	7/22/2016 13:17	8/2/2016	44162	COPPER	0.4 PPM	1.3 PPM
59-44A Room 7 Sink Faucet	7/22/2016 13:20	8/2/2016	44163	COPPER	0.3 PPM	1.3 PPM
59-45A Room 7 Drinking Fountain	7/22/2016 13:22	8/2/2016	44164	COPPER	0.4 PPM	1.3 PPM
59-46A Room 8 Sink Faucet	7/22/2016 13:24	8/2/2016	44165	COPPER	0.3 PPM	1.3 PPM
59-47A Room 8 Drinking Fountain	7/22/2016 13:26	8/2/2016	44166	COPPER	0.4 PPM	1.3 PPM
59-48A Gymnasium Drinking Fountain	7/22/2016 13:30	8/2/2016	44167	COPPER	0.3 PPM	1.3 PPM
59-49A Music Room Sink Faucet	7/22/2016 13:32	8/2/2016	44168	COPPER	0.4 PPM	1.3 PPM
59-50A Music Room Drinking Fountain	7/22/2016 13:34	8/2/2016	44169	COPPER	0.5 PPM	1.3 PPM
59-51A Main Corridor Outside Media Center Drinking Fountain (left)	7/22/2016 13:45	8/2/2016	44170	COPPER	0.2 PPM	1.3 PPM
59-52A Main Corridor Outside Media Center Drinking Fountain (right)	7/22/2016 13:47	8/2/2016	44171	COPPER	0.4 PPM	1.3 PPM
59-53A Main Corridor Near Room 6 Drinking Fountian	7/22/2016 13:49	8/2/2016	44172	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**