

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-01A Gymnasium West Side Drinking Fountain (Left)	7/23/2016 6:15	7/28/2016	43484	COPPER	0.5 PPM	1.3 PPM
61-02A Gymnasium West Side Drinking Fountain (Right)	7/23/2016 6:17	7/28/2016	43485	COPPER	0.5 PPM	1.3 PPM
61-03A Gymnasium East Side Drinking Fountain (Left)	7/23/2016 6:19	7/28/2016	43486	COPPER	0.5 PPM	1.3 PPM
61-04A Gymnasium East Side Drinking Fountain (Right)	7/23/2016 6:21	7/28/2016	43487	COPPER	0.4 PPM	1.3 PPM
61-05A E115 Training Room Sink Faucet	7/23/2016 6:28	7/28/2016	43488	COPPER	0.4 PPM	1.3 PPM
61-06A E115 Training Room Ice Machine	7/23/2016 6:30	7/28/2016	43489	COPPER	<0.005 PPM	1.3 PPM
61-07A Girls Locker Room Drinking Fountain	7/23/2016 6:36	7/28/2016	43490	COPPER	0.5 PPM	1.3 PPM
61-08A Girls Locker Room Bottle Refill Station	7/23/2016 6:38	7/28/2016	43491	COPPER	0.5 PPM	1.3 PPM
61-09A Boys Locker Room Drinking Fountain	7/23/2016 6:40	7/28/2016	43492	COPPER	0.4 PPM	1.3 PPM
61-10A Boys Locker Room Bottle Refill Station	7/23/2016 6:42	7/28/2016	43493	COPPER	0.4 PPM	1.3 PPM
61-11A D-103 Sink Faucet	7/23/2016 6:44	7/28/2016	43494	COPPER	0.3 PPM	1.3 PPM
61-12A Food Lab D-128 Sink Faucet 1	7/23/2016 6:46	7/28/2016	43495	COPPER	0.4 PPM	1.3 PPM
61-13A Food Lab D-128 Sink Faucet 2	7/23/2016 6:48	7/28/2016	43496	COPPER	0.4 PPM	1.3 PPM
61-14A Food Lab D-128 Sink Faucet 3	7/23/2016 6:50	7/28/2016	43497	COPPER	0.4 PPM	1.3 PPM
61-15A Food Lab D-128 Sink Faucet 4	7/23/2016 6:52	7/28/2016	43498	COPPER	0.3 PPM	1.3 PPM
61-16A Food Lab D-128 Sink Faucet 5	7/23/2016 6:54	7/28/2016	43499	COPPER	0.4 PPM	1.3 PPM
61-17A Food Lab D-128 Sink Faucet 6	7/23/2016 6:56	7/28/2016	43500	COPPER	0.4 PPM	1.3 PPM
61-18A D Hall Drinking Fountain (Left)	7/23/2016 6:58	7/28/2016	43501	COPPER	0.6 PPM	1.3 PPM
61-19A D Hall Drinking Fountain (Middle)	7/23/2016 7:00	7/28/2016	43502	COPPER	0.6 PPM	1.3 PPM
61-20A D Hall Drinking Fountain (Right)	7/23/2016 7:02	7/28/2016	43503	COPPER	0.6 PPM	1.3 PPM
61-21A D Hall Bottle Refill Station	7/23/2016 7:04	7/28/2016	43504	COPPER	0.6 PPM	1.3 PPM
61-22A D-134 Sink Faucet	7/23/2016 7:06	7/28/2016	43505	COPPER	0.4 PPM	1.3 PPM
61-23A D-107 Sink Faucet	7/23/2016 7:08	7/28/2016	43506	COPPER	0.4 PPM	1.3 PPM
61-24A Kitchen Sink Faucet Across From Freezer	7/23/2016 7:10	7/28/2016	43507	COPPER	0.2 PPM	1.3 PPM
61-25A Kitchen Sink Faucet (Left) Across From Dish Washer	7/23/2016 7:12	7/28/2016	43508	COPPER	0.4 PPM	1.3 PPM
61-26A Kitchen Sink Faucet (Right) Across From Dish Washer	7/23/2016 7:14	7/28/2016	43509	COPPER	0.2 PPM	1.3 PPM
61-27A Kitchen Ice Machine	7/23/2016 7:16	7/28/2016	43510	COPPER	<0.005 PPM	1.3 PPM
61-28A C-105 Student Store Sink Faucet	7/23/2016 7:18	7/28/2016	43511	COPPER	0.4 PPM	1.3 PPM
61-29A Main Office Sink Faucet	7/23/2016 7:20	7/28/2016	43512	COPPER	0.4 PPM	1.3 PPM
61-30A C112J Kitchen Sink Faucet	7/23/2016 7:22	7/28/2016	43513	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-31A C112F Student Health Sink Faucet	7/23/2016 7:24	7/28/2016	43514	COPPER	0.4 PPM	1.3 PPM
61-32A B-113 Sink Faucet	7/23/2016 7:26	7/28/2016	43515	COPPER	0.4 PPM	1.3 PPM
61-33A B-112 Sink Faucet	7/23/2016 7:28	7/28/2016	43516	COPPER	0.4 PPM	1.3 PPM
61-34A B Hall Drinking Fountain (Left)	7/23/2016 7:30	7/28/2016	43517	COPPER	0.5 PPM	1.3 PPM
61-35A B Hall Drinking Fountain (Right)	7/23/2016 7:32	7/28/2016	43518	COPPER	0.5 PPM	1.3 PPM
61-36A B-104 Sink Faucet	7/23/2016 7:34	7/28/2016	43519	COPPER	0.3 PPM	1.3 PPM
61-37A B-105 Sink Faucet	7/23/2016 7:36	7/28/2016	43520	COPPER	0.5 PPM	1.3 PPM
61-38A A116/117 Sink Faucet East Wall	7/23/2016 7:38	7/28/2016	43521	COPPER	0.6 PPM	1.3 PPM
61-39A A116/117 Sink Faucet South Wall	7/23/2016 7:40	7/28/2016	43522	COPPER	0.3 PPM	1.3 PPM
61-40A A115 Sink Faucet North Wall	7/23/2016 7:42	7/28/2016	43523	COPPER	0.6 PPM	1.3 PPM
61-41A A115 Sink Faucet East Wall	7/23/2016 7:44	7/28/2016	43524	COPPER	0.6 PPM	1.3 PPM
61-42A A Hall Drinking Fountain (Left)	7/23/2016 7:46	7/28/2016	43525	COPPER	0.6 PPM	1.3 PPM
61-43A A Hall Drinking Fountain (Right)	7/23/2016 7:48	7/28/2016	43526	COPPER	0.6 PPM	1.3 PPM
61-44A A102 Drinking Fountain	7/23/2016 7:50	7/28/2016	43527	COPPER	0.8 PPM	1.3 PPM
61-45A A102C Instrument Storage Sink Faucet	7/23/2016 7:52	7/28/2016	43528	COPPER	0.5 PPM	1.3 PPM
61-46A A101 Drinking Fountain	7/23/2016 7:54	7/28/2016	43529	COPPER	1.0 PPM	1.3 PPM
61-47A A100 Drinking Fountain	7/23/2016 7:56	7/28/2016	43530	COPPER	1.0 PPM	1.3 PPM
61-48A 2nd Floor B Hall Drinking Fountain (Left)	7/23/2016 7:58	7/28/2016	43531	COPPER	0.6 PPM	1.3 PPM
61-49A 2nd Floor B Hall Drinking Fountain (Right)	7/23/2016 8:00	7/28/2016	43532	COPPER	0.6 PPM	1.3 PPM
61-50A B-202 Sink Faucet	7/23/2016 8:02	7/28/2016	43533	COPPER	0.3 PPM	1.3 PPM
61-51A B-202 Sink Faucet	7/23/2016 8:04	7/28/2016	43534	COPPER	0.3 PPM	1.3 PPM
61-52A B-203 Sink Faucet (Right)	7/23/2016 8:06	7/28/2016	43535	COPPER	0.4 PPM	1.3 PPM
61-53A B-203 Sink Faucet (Left)	7/23/2016 8:08	7/28/2016	43536	COPPER	0.3 PPM	1.3 PPM
61-54A B-209 Sink Faucet	7/23/2016 8:10	7/28/2016	43537	COPPER	0.4 PPM	1.3 PPM
61-55A Library Hall Drinking Fountain (Left)	7/23/2016 8:12	7/28/2016	43538	COPPER	0.8 PPM	1.3 PPM
61-56A Library Hall Drinking Fountain (Right)	7/23/2016 8:14	7/28/2016	43539	COPPER	0.7 PPM	1.3 PPM
61-57A Library Workroom C202 Sink Faucet	7/23/2016 8:16	7/28/2016	43540	COPPER	0.4 PPM	1.3 PPM
61-58A D-203 Sink Faucet	7/23/2016 8:18	7/28/2016	43541	COPPER	0.4 PPM	1.3 PPM
61-59A D-227 Sink Faucet (Left)	7/23/2016 8:20	7/28/2016	43542	COPPER	0.4 PPM	1.3 PPM
61-60A D-227 Sink Faucet (Right)	7/23/2016 8:22	7/28/2016	43543	COPPER	0.4 PPM	1.3 PPM

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-61A D-226 Sink Faucet	7/23/2016 8:24	7/28/2016	43544	COPPER	0.4 PPM	1.3 PPM
61-62A D-225 Sink Faucet	7/23/2016 8:26	7/28/2016	43545	COPPER	0.4 PPM	1.3 PPM
61-64A D Wing Drinking Fountain (Left)	7/23/2016 8:28	7/28/2016	43546	COPPER	0.5 PPM	1.3 PPM
61-65A D Wing Drinking Fountain (Right)	7/23/2016 8:30	7/28/2016	43547	COPPER	0.5 PPM	1.3 PPM
61-66A Upper Gymnasium Drinking Fountain (Left)	7/23/2016 8:32	7/28/2016	43548	COPPER	0.4 PPM	1.3 PPM
61-67A Upper Gymnasium Drinking Fountain (Right)	7/23/2016 8:34	7/28/2016	43549	COPPER	0.5 PPM	1.3 PPM
61-68A 2nd Floor Gymnasium Snack Bar Sink Faucet	7/23/2016 8:36	7/28/2016	43550	COPPER	0.4 PPM	1.3 PPM
61-69A Gymnasium Hall Drinking Fountain 2nd Floor	7/23/2016 8:38	7/28/2016	43551	COPPER	0.4 PPM	1.3 PPM
61-70A 1st Floor Gymnasium Hall Drinking Fountain (Left)	7/23/2016 6:24	7/28/2016	43552	COPPER	0.5 PPM	1.3 PPM
61-71A 1st Floor Gymnasium Hall Drinking Fountain (Right)	7/23/2016 6:26	7/28/2016	43553	COPPER	0.5 PPM	1.3 PPM
61-72A Outside Snack Shack Drinking Fountain (Left)	7/23/2016 8:43	7/28/2016	43554	COPPER	0.7 PPM	1.3 PPM
61-73A Outside Snack Shack Drinking Fountain (Right)	7/23/2016 8:45	7/28/2016	43555	COPPER	0.7 PPM	1.3 PPM
61-74A Outside Snack Shack Inside	7/23/2016 8:47	7/28/2016	43556	COPPER	0.3 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
61-63A D-224 Sink Faucet	9/29/2016 4:54	10/3/2016	59447	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level

Salem-Keizer Public Schools
Copper Water Sampling Results
First Draw (A) Sample Data
West Salem High School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Results	Action Level
061-75A 2nd Floor Gym Hall Bottle Filler w/76	1/6/2017 7:15	1/9/2017	794	COPPER	0.5 PPM	1.3 PPM
061-76A 2nd Floor Gym Hall Drinking Fountain w/75	1/6/2017 7:15	1/9/2017	795	COPPER	0.4 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level