

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Wright Elementary School

Sample Identification # and Location		Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result		Action Level
041-01A	Auditorium/Cafeteria Drinking Fountain	7/14/16 7:00	7/23/2016	1607813-01A	COPPER	0.0	PPM	1.3 PPM
041-02A	Room 12 Sink Faucet	7/14/16 7:20	7/23/2016	1607813-02A	COPPER	0.0	PPM	1.3 PPM
041-03A	Room 12 Drinking Fountain	7/14/16 7:22	7/23/2016	1607813-03A	COPPER	0.1	PPM	1.3 PPM
041-04A	Room 13 Sink Faucet	7/14/16 7:28	7/23/2016	1607813-04A	COPPER	0.0	PPM	1.3 PPM
041-05A	Room 13 Drinking Fountain	7/14/16 7:30	7/23/2016	1607813-05A	COPPER	0.1	PPM	1.3 PPM
041-06A	Room 14 Sink Faucet	7/14/16 7:47	7/23/2016	1607813-06A	COPPER	0.1	PPM	1.3 PPM
041-07A	Room 14 Drinking Fountain	7/14/16 7:49	7/23/2016	1607813-07A	COPPER	0.1	PPM	1.3 PPM
041-08A	Room 15 Sink Faucet	7/14/16 7:40	7/23/2016	1607813-08A	COPPER	0.0	PPM	1.3 PPM
041-09A	Room 15 Drinking Fountain	7/14/16 7:42	7/23/2016	1607813-09A	COPPER	0.1	PPM	1.3 PPM
041-10A	Hall Corridor D Drinking Fountain 1	7/14/16 7:53	7/23/2016	1607813-10A	COPPER	0.7	PPM	1.3 PPM
041-11A	Room 16 Sink Faucet	7/14/16 8:00	7/23/2016	1607813-11A	COPPER	0.0	PPM	1.3 PPM
041-12A	Room 16 Drinking Fountain	7/14/16 8:02	7/23/2016	1607813-12A	COPPER	0.1	PPM	1.3 PPM
041-13A	Room 19 Sink Faucet	7/14/16 8:05	7/23/2016	1607813-13A	COPPER	0.0	PPM	1.3 PPM
041-14A	Room 19 Drinking Fountain	7/14/16 8:07	7/23/2016	1607813-14A	COPPER	<0.005	PPM	1.3 PPM
041-15A	Hall Corridor D Drinking Fountain 2	7/14/16 8:10	7/23/2016	1607813-15A	COPPER	0.6	PPM	1.3 PPM
041-16A	Hall Corridor D Drinking Fountain 3	7/14/16 8:12	7/23/2016	1607813-16A	COPPER	0.5	PPM	1.3 PPM
041-17A	Room 21 Sink Faucet	7/14/16 8:15	7/23/2016	1607813-17A	COPPER	0.3	PPM	1.3 PPM
041-18A	Room 21 Drinking Fountain	7/15/16 8:17	7/23/2016	1607813-18A	COPPER	0.5	PPM	1.3 PPM
041-19A	Room 23 Sink Faucet	7/14/16 8:20	7/23/2016	1607813-19A	COPPER	0.3	PPM	1.3 PPM
041-20A	Room 23 Drinking Fountain	7/14/16 8:22	7/23/2016	1607813-20A	COPPER	0.6	PPM	1.3 PPM
041-21A	Room 18 Sink Faucet	7/14/16 8:25	7/23/2016	1607813-21A	COPPER	0.3	PPM	1.3 PPM
041-22A	Room 18 Drinking Fountain	7/14/16 8:27	7/23/2016	1607813-22A	COPPER	0.7	PPM	1.3 PPM
041-23A	Room 22 Sink Faucet	7/14/16 8:30	7/23/2016	1607813-23A	COPPER	0.4	PPM	1.3 PPM
041-24A	Room 22 Drinking Fountain	7/14/16 8:32	7/23/2016	1607813-24A	COPPER	0.7	PPM	1.3 PPM
041-25A	Room 20 Sink Faucet	7/14/16 8:35	7/23/2016	1607813-25A	COPPER	0.3	PPM	1.3 PPM
041-26A	Room 20 Drinking Fountain	7/14/16 8:37	7/23/2016	1607813-26A	COPPER	0.7	PPM	1.3 PPM
041-27A	Staff Lounge Sink Faucet 1	7/14/16 7:12	7/23/2016	1607813-27A	COPPER	0.0	PPM	1.3 PPM

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (A) Sample Data  
Wright Elementary School

041-28A	Staff Lounge Sink Faucet 2	7/14/16 7:10	7/23/2016	1607813-28A	COPPER	0.0	PPM	1.3 PPM
041-29A	Nurse Office Sink Faucet	7/14/16 8:45	7/23/2016	1607813-29A	COPPER	0.0	PPM	1.3 PPM
041-30A	Nurse Office Drinking Fountain	7/14/16 8:47	7/23/2016	1607813-30A	COPPER	0.0	PPM	1.3 PPM
041-31A	Hallway Corridor B Drinking Fountain	7/14/16 8:50	7/23/2016	1607813-31A	COPPER	0.0	PPM	1.3 PPM
041-32A	Room 9 Sink Faucet	7/14/16 8:54	7/23/2016	1607813-32A	COPPER	0.0	PPM	1.3 PPM
041-33A	Room 9 Drinking Fountain	7/14/16 8:56	7/23/2016	1607813-33A	COPPER	0.0	PPM	1.3 PPM
041-34A	Room 8 Sink Faucet	7/14/16 8:59	7/23/2016	1607813-34A	COPPER	0.0	PPM	1.3 PPM
041-35A	Room 8 Drinking Fountain	7/14/16 9:01	7/23/2016	1607813-35A	COPPER	<0.005	PPM	1.3 PPM
041-36A	Room 6 Sink Faucet	7/14/16 9:05	7/23/2016	1607813-36A	COPPER	0.3	PPM	1.3 PPM
041-37A	Room 6 Drinking Fountain	7/14/16 9:07	7/23/2016	1607813-37A	COPPER	0.0	PPM	1.3 PPM
041-38A	Room 7 Sink Faucet	7/14/16 9:11	7/23/2016	1607813-38A	COPPER	0.0	PPM	1.3 PPM
041-39A	Room 7 Drinking Fountain	7/14/16 9:13	7/23/2016	1607813-39A	COPPER	0.0	PPM	1.3 PPM
041-40A	Room 5 Sink Faucet	7/14/16 9:18	7/23/2016	1607813-40A	COPPER	0.0	PPM	1.3 PPM
041-41A	Room 5 Drinking Fountain	7/14/16 9:20	7/23/2016	1607813-41A	COPPER	0.0	PPM	1.3 PPM
041-42A	Room 4 Sink Faucet	7/14/16 9:25	7/23/2016	1607813-42A	COPPER	0.0	PPM	1.3 PPM
041-43A	Room 4 Drinking Fountain	7/14/16 9:27	7/23/2016	1607813-43A	COPPER	0.1	PPM	1.3 PPM
041-44A	Room 3 Sink Faucet	7/14/16 9:37	7/23/2016	1607813-44A	COPPER	0.1	PPM	1.3 PPM
041-45A	Room 3 Drinking Fountain	7/14/16 9:39	7/23/2016	1607813-45A	COPPER	0.0	PPM	1.3 PPM
041-46A	Room 1 Sink Faucet	7/14/16 9:43	7/23/2016	1607813-46A	COPPER	0.1	PPM	1.3 PPM
041-47A	Room 1 Drinking Fountain	7/14/16 9:45	7/23/2016	1607813-47A	COPPER	0.0	PPM	1.3 PPM
041-48A	Room 2 Sink Faucet	7/14/16 9:30	7/23/2016	1607813-48A	COPPER	0.0	PPM	1.3 PPM
041-49A	Room 2 Drinking Fountain	7/14/16 9:32	7/23/2016	1607813-49A	COPPER	0.1	PPM	1.3 PPM
041-50A	Hall Corridor A Drinking Fountain 4	7/14/16 9:49	7/23/2016	1607813-50A	COPPER	0.1	PPM	1.3 PPM
041-51A	Music Room Sink Faucet	7/14/16 9:53	7/23/2016	1607813-51A	COPPER	0.3	PPM	1.3 PPM
041-52A	Music Room Drinking Fountain	7/14/16 9:55	7/23/2016	1607813-52A	COPPER	0.6	PPM	1.3 PPM
041-53A	Gymnasium Drinking Fountain	7/14/16 9:59	7/23/2016	1607813-53A	COPPER	0.3	PPM	1.3 PPM
041-54A	Room 17 Sink Faucet	7/14/16 7:40	7/23/2016	1607813-54A	COPPER	0.2	PPM	1.3 PPM
041-55A	Room 17 Drinking Fountain	7/14/16 7:42	7/23/2016	1607813-55A	COPPER	0.4	PPM	1.3 PPM
041-57A	Kitchen Food Prep #1 Sink Faucet	7/14/16 7:02	7/23/2016	1607813-56A	COPPER	0.1	PPM	1.3 PPM

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 First Draw (A) Sample Data  
 Wright Elementary School

041-58A	Kitchen Food Prep #2 Sink Faucet	7/14/16 7:04	7/23/2016	1607813-57A	COPPER	0.0	PPM	1.3 PPM
041-59A	Kitchen Food Prep #3 Sink Faucet	7/14/16 7:06	7/25/2016	1607813-58A	COPPER	0.0	PPM	1.3 PPM
EPA Action Level for Copper in Schools is 1.3 PPM								
SKPS Action Level for Copper is 1.3 PPM								
<b>Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level</b>								

Salem-Keizer Public Schools  
 Copper Water Sampling Results  
 Flushed (B) Sample Data  
 Wright Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
041-04B Room 13 Sink Faucet	7/14/16 7:29	8/7/2016	1607814-04A	COPPER	<0.005 PPM	1.3 PPM
041-32B Room 9 Sink Faucet	7/14/16 8:55	8/7/2016	1607814-32A	COPPER	<0.005 PPM	1.3 PPM
041-36B Room 6 Sink Faucet	7/14/16 9:06	8/7/2016	1607814-36A	COPPER	<0.005 PPM	1.3 PPM
041-38B Room 7 Sink Faucet	7/14/16 9:12	8/7/2016	1607814-38A	COPPER	<0.005 PPM	1.3 PPM
041-47B Room 1 Drinking Fountain	7/14/16 9:46	8/7/2016	1607814-47A	COPPER	0.1 PPM	1.3 PPM
041-57B Kitchen Food Prep #1 Sink Faucet	7/14/16 7:03	8/7/2016	1607814-56A	COPPER	<0.005 PPM	1.3 PPM
EPA Action Level for Copper in Schools is 1.3 PPM						
SKPS Action Level for Copper is 1.3 PPM						
<b>Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level</b>						

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (C) Sample Data  
Wright Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
041-04C Room 13 Sink Faucet	9/29/2016 6:24	10/3/2016	59456	COPPER	0.1 PPM	1.3 PPM
041-32C Room 9 Sink Faucet	9/29/2016 6:27	10/3/2016	59457	COPPER	0.2 PPM	1.3 PPM
041-36C Room 6 Sink Faucet	9/29/2016 6:33	10/3/2016	59458	COPPER	0.1 PPM	1.3 PPM
041-38C Room 7 Sink Faucet	9/29/2016 6:38	10/3/2016	59459	COPPER	0.1 PPM	1.3 PPM
041-47C Room 1 Drinking Fountain	9/29/2016 6:44	10/3/2016	59460	COPPER	0.1 PPM	1.3 PPM
041-57C Kitchen Food Prep #1 Sink Faucet	9/29/2016 6:49	10/3/2016	59461	COPPER	0.0 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

**SKPS Action Level for Copper is 1.3 PPM**

**Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level**

Salem-Keizer Public Schools  
Copper Water Sampling Results  
First Draw (E) Sample Data  
Wright Elementary School

Sample Identification # and Location	Date/Time Sampled	Date Analyzed	Container ID	Tested For	Result	Action Level
041-32E Room 9 Sink Faucet	3/16/2017 6:08	3/17/2017	13881	COPPER	0.0 PPM	1.3 PPM
041-38E Room 7 Sink Faucet	3/16/2017 6:13	3/17/2017	13882	COPPER	0.0 PPM	1.3 PPM
041-47E Room 1 Drinking Fountain	3/16/2017 6:18	3/17/2017	13883	COPPER	0.2 PPM	1.3 PPM

EPA Action Level for Copper in Schools is 1.3 PPM

SKPS Action Level for Copper is 1.3 PPM

Highlighted samples are at or exceed the Salem-Keizer Public Schools (SKPS) Action Level